



Date Submitted: 1/22/2014

## Water Use Efficiency Annual Performance Report - 2013

WS Name: LWWS - AGATE HEIGHTS

Water System ID# : 52957

WS County: WHATCOM

Report submitted by: *kevin cook*

### Meter Installation Information:

Estimate the percentage of metered connections: *100%*

If not fully metered - Current status of meter installation:

### Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: *01/01/2013* To *12/31/2013*

Incomplete or missing data for the year? *No*

If yes, explain:

### Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	<i>3,418,928</i> gallons
Authorized Consumption (AC) – Annual Volume	<i>3,382,246</i> gallons
Distribution System Leakage – Annual Volume TP – AC	<i>36,682</i> gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	<i>1.1 %</i>
3-year annual average	<i>3.9 %</i>

### Goal-Setting Information:

Date of Most Recent Public Forum: *06/22/2010* Has goal been changed since last performance report? *No*

Note: Customer goal must be re-established every 6 years through a public process

### WUE Goals:

Customer Goal (Demand Side):

*Reduce our per capita per day, July and August demand by 2% by 2015*

### Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

### Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently: