



Date Submitted: 1/21/2014

Water Use Efficiency Annual Performance Report - 2013

WS Name: LWWS - EAGLERIDGE

Water System ID# : 08118

WS County: WHATCOM

Report submitted by: *kevin cook*

Meter Installation Information:

Estimate the percentage of metered connections: 100%

If not fully metered - Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: 01/01/2013 To 12/31/2013

Incomplete or missing data for the year? No

If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	706,345 gallons
Authorized Consumption (AC) – Annual Volume	696,358 gallons
Distribution System Leakage – Annual Volume TP – AC	9,987 gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	1.4 %
3-year annual average	3.1 %

Goal-Setting Information:

Date of Most Recent Public Forum: 06/22/2010 Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

Reduce summer peak usage by 25%, reduce annual average per capita 2% by 2015.

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently: