



Date Submitted: 3/8/2011

## Water Use Efficiency Annual Performance Report - 2010

WS Name: LWWSD - AGATE HEIGHTS

Water System ID# : 52957

WS County: WHATCOM

Report submitted by: Kevin Cook

### Meter Installation Information:

Is your water system fully metered? Yes

If not fully metered - Current status of meter installation:

### Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: 12/31/2009 To 12/31/2010

Incomplete or missing data for the year? No

If yes, explain:

### Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	3,190,923 gallons
Authorized Consumption (AC) – Annual Volume	2,976,501 gallons
Distribution System Leakage – Annual Volume TP – AC	214,422 gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	6.7 %
3-year annual average	8.7 %

### Goal-Setting Information:

Date of Most Recent Public Forum: 06/22/2010 Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process

### WUE Goals:

Customer Goal (Demand Side):

*Reduce our per capita, per day July & August demand by 2% by 2015.*

### Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

### Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently: