



---

TO: Bill Hunter, PE, LWWS

FROM: Brian Smith, PE and Ben Gibson, PE *Brian M. Smith*

SUBJECT: Fire Flow Improvements – Friction Factor Flow Testing

DATE: January 18, 2021, updated December 28, 2021 to include Attachment 2

---

## Introduction

The District's 2017 Water System Plan identified a need for further calibration of the hydraulic model for the District's South Shore water system. The data and analysis contained in this technical memorandum are an effort to refine the Hazen-Williams C value used in the hydraulic model for the South Shore system. Doing so will help to calibrate the hydraulic model to more accurately reflect real-life system performance and identify needed improvements. Specifically, the results of this analysis will help to determine whether certain previously-identified areas within the South Shore system are capable of providing 500 gpm fire flows while maintaining 20 psi throughout the system. These areas (junctions J1428 and J1914 in the model) are discussed in further detail in the attached "LWWS South Shore Fire Flow Analysis" technical memorandum, submitted to the District in May, 2018.

## Executive Summary

Five unidirectional flush tests were performed on pipes within the District's South Shore water system. The collected data resulted in C values of 127, 127, 84, 126, and 105, for an average of 114. To be conservative, a C value of 100 is recommended for the Sudden Valley portion of the District's South Shore water system. This modifies the 2017 Water System Plan information in which a C factor of 70 was applied to the Sudden Valley portion of the water system. Reasons for the change are discussed in this report. The hydraulic model was updated to reflect the new recommendation of a C value of 100, and this change results in all of the fire hydrants within the South Shore system being capable of providing 500 gpm while maintaining 20 psi throughout the system, as required by DOH.

## **Analysis**

### *Background*

As part of the 2017 Water System Plan, some limited flushing data was collected and analyzed that resulted in the recommendation to apply a C value of 70 for the Sudden Valley portion of the distribution system (see Appendix E of WSP). The data collected represented only a small portion of the distribution system, and the flushing that was done was not unidirectional but instead occurred at a location near the pressure data logger. Because flushing was not unidirectional, the magnitude of the measured pressure drops was quite low, making it susceptible to system variabilities. For these reasons, it was decided for this current effort to collect additional data from portions of the distribution system where flushing could be unidirectional and headloss could be precisely quantified for a given segment of distribution pipe.

### *Data Collection*

The general approach for collecting the data necessary for this analysis consisted of isolating a section of pipe to obtain unidirectional flow by closing the necessary valves, installing data loggers at two locations along the isolated pipe, and then flushing the line by opening a hydrant and monitoring the flowrate out of the hydrant. The data loggers recorded the water pressure at 30 second intervals before, during, and after the flush. The lines were flushed for a minimum of five minutes in order to stabilize the pressures and provide a sufficient dataset.

Flushing data was collected from five pipe sections within the South Shore system, as shown in Figure 1. These pipe sections are referred to in this analysis as Stable Lane, Jubilee, Sunnyside, Lost Lake, and Polo Park. District staff performed the flushes and data collection, and provided the data to Wilson Engineering.




Figure 1 – LWWSD South Shore System Data Collection Locations

Figures 2-6 show graphs of the pressures recorded by each data logger before, during, and after the flush for each section of pipe (except for Sunnyside, where post-flush data is not available because the logger was removed from the hydrant immediately following the flush). In general these graphs show reasonable trends, with the exception of a few fluctuations in the recorded pressures. These outliers are most likely due to pressure transients, but could also be instances of pressure drops due to local demands (unlikely), or simply equipment issues. Whatever the case, these outliers were omitted when calculating average pressures before/after and during each flush.




Figure 2 – Stable Lane Pressure Graph




Figure 3 – Jubilee Pressure Graph




Figure 4 – Sunnyside Pressure Graph




Figure 5 – Lost Lake Pressure Graph




Figure 6 – Polo Park Pressure Graph

One interesting trend shown in Figures 2-6 is that the post-flush pressure consistently does not recover to the pre-flush pressure, at least not within the ~5 minutes that the logger remains in place after the flush. The primary explanation for this relates to the system’s Pressure Reducing Valves (PRVs). With the exception of Stable Lane, all of these zones are fed through PRV stations that control zone pressures, and each station consists of two PRVs: a smaller one, which handles lower flows, and a larger one which handles the larger flows (fire flow). The larger PRV is set to a slightly lower downstream pressure than the smaller PRV so that the typical domestic demand preferentially goes through the smaller PRV. So, one explanation is that system pressures are regulated by the smaller PRV before the flush occurs, and then flushing triggers the larger PRV to control pressure during flush, and for some interval after the flush (the time for this depends on there being demand in the system and getting flow through the PRV station for the small PRV to regain control of the downstream pressure setpoint). Both pre- and post-flush pressures were taken into account when calculating recommended C values, which is discussed in further detail in the following *Headloss Calculations* section.

#### *Data Reliability*

In the flush tests at Stable and Jubilee (data collected in 2019), flow was measured as a volume with a meter, and the amount of time per 100 gallons was recorded. This seems to have resulted in a fairly accurate and precise flow rate. For the Sunnyside, Lost Lake, and Polo Park flushes (data collected in 2020), a different meter was utilized, which provided instantaneous flowrates instead of volume. This appears to have diminished the precision of the recorded flowrate. The observed flows were reported as a range with between 7% and 37% difference (presumably because the flow rate on the display was fluctuating between these values during the flush). As such, the mean value of the given range was utilized for headloss calculations.

It is worth noting that for future flush tests, it is important that the flow be recorded as accurately as possible during flushing. The formula for calculating headloss involves a multiplier of “velocity raised to the 1.85”, so any deviation in flow gets compounded and can significantly influence the results.

*Headloss Calculations*

The “observed” headloss for each section of pipe was derived using a form of Bernoulli’s equation with the recorded pressures from both data loggers before and after (averaged) and during the flush. Using this observed headloss, as well as the observed flow rate and known pipe characteristics, the C value for each pipe section was calculated using the Hazen-Williams equation, and are summarized in Table 1.

Table 1: Pipe Characteristics

	Stable Lane	Jubilee	Sunnyside	Lost Lake	Polo Park
Pipe Diameter	6 inch	6 inch	6 inch	6 inch	8 inch
Pipe Length (distance between data loggers)	900 ft	574 ft	405 ft	258 ft	448 ft
Average Observed Flowrate(s) <sup>1</sup>	318 gpm 363 gpm	515 gpm	425 gpm	675 gpm	475 gpm
Observed Headloss(es) <sup>1</sup>	8.88 ft 10.58 ft	13.70 ft	13.76 ft	9.79 ft	3.11 ft
Calculated C value <sup>1</sup>	<b>127</b>	<b>127</b>	<b>84</b>	<b>126</b>	<b>105</b>

1. Two flush tests were performed for Stable Lane. The resultant C values for both tests were then averaged.

As discussed previously, the recorded pressures after flushing (post-flush) are consistently lower than before flushing (by about 5-15 psi, with the only exception being Stable Lane 1, which makes sense because Stable Lane is fed by gravity from the Div 22 reservoir instead of through a PRV station). As such, separate headlosses were calculated based on the pre-flush, post-flush, and average pre/post-flush pressures (compared to average pressure during flushing). This resulted in a range of C values, which are summarized in Table 2. While calculations based on comparison to post-flush pressures is likely the most accurate given the previous description and concept that pressure during and immediately after the flush is controlled by the larger of the two PRVs in the PRV station, we analyzed the data and concluded that averaging the C values from pre- and post-flush pressures is slightly more conservative. Therefore these are the values that are reported in the Executive Summary. The only exception to this is the Sunnyside data because the data logger was removed immediately following the flush and no post-flush pressure data was collected.

Table 2 – C Values based on Pre-, Post-, and Average of Pre- and Post-Flush Pressures

	Pre-Flush	Post-Flush	Average Pre/Post	
Stable Lane 1	137	115	<b>125</b>	<b>127</b>
Stable Lane 2	113	156	<b>130</b>	
Jubilee	122	132	<b>127</b>	
Sunnyside	<b>84</b>	--	--	
Lost Lake	124	129	<b>126</b>	
Polo Park	100	109	<b>105</b>	

### Discussion

The average of the calculated C values (bold values in Table 2) from the five flushing locations is 114. The Ductile Iron Pipe Research Association (DIPRA) recommends a C value of 140 for the design of new pipe networks, which they claim for cement lined pipe (a standard feature for ductile iron pipe since the 40's), is valid for the life of the pipe (*Cement-Mortar Linings for Ductile Iron Pipe*, DIPRA, 2017). However, for cast iron pipe, where cement lining has historically not been the norm, the C value declines over time due to tuberculation within the pipe. This could help to explain the broad range of resulting C values – particularly the lower values of 84 and 105. Based on a number of documented “full-circle” water main breaks in the South Shore system, it appears that portions of the system may be cast iron (which is more brittle than ductile iron, and thus more prone to full-circle breaks). Based on the collected data, we hypothesize that the tested portion of the Sunnyside main, and perhaps the Polo Park main, could be unlined cast iron pipe. Future flushing, data collection, and analysis could potentially be used to identify segments of cast iron pipe.

### Summary of Previous Calibration Efforts

The current Water System Plan (updated 2017), Appendix E, addresses the most recent model calibration effort and resulting parameters, prior to this current effort. Flushing and data collection had been performed in Sudden Valley as part of that effort, and it resulted in a recommended C value of 70 for the Sudden Valley portion of the south shore system. The recommended C value for the Geneva portion of the south shore system remained 100.

For context, the previous flushing effort simply opened hydrants and recorded pressures and flows. It did not identify pipe segments that could be isolated to perform a unidirectional flush as the current data collection performed. It is expected that the unidirectional flushing as part of the current effort resulted in a greater magnitude of headloss during the flush and minimization of other factors that could influence the results and interpretation of results. Therefore, we

recommend that the current data and analysis replace the previous analysis and recommendations.

## **Recommendations**

Based on these findings, a C value of 100 is recommended for the entire South Shore system hydraulic model (Sudden Valley and Geneva). The value of 100 should be conservative (below the average measured value) and accounts for the possible mix of ductile iron and cast iron pipes within the system.

### *Impacts*

The previous C value of 70 for the Sudden Valley portion of the South shore system resulted in an apparent system deficiency due to a number of fire hydrants that were unable to provide 500 gpm flow while maintaining the minimum system pressure of 20 psi. This is discussed in further detail in the “LWWSD South Shore Fire Flow Analysis” technical memorandum, attached for reference. Specifically, page 3 of the memo states:

*“The reason these two junctions (hydrants) are currently problems is due to the newly-adjusted C factor for all pipes in Sudden Valley. The calibration effort described in the WSP determined that a C factor of 70 was appropriate for the limited areas where flow testing occurred. But pipes in the vicinity of Basinview and Highwood were not tested. It is possible that a C factor of 70 is not appropriate for these pipes. If the C factor in these vicinities is re-assessed and found to be 95 or greater, they will be capable of providing 500 gpm at 20 psi. Results for these scenarios are shown in Tables 3B-1 and 3C-1.*

*If the C factor is assessed and found to be less than 95, there are segments of existing pipe near each of these hydrants that could be replaced with new 8-inch pipe that would solve the pressure issue. These would be on the order of a couple hundred feet of new 8-inch pipe for each.”*

Therefore, since the appropriate C-factor was determined to be 100, the noted junctions (model nodes J1429 and J1914) are not problematic.

We updated the south shore hydraulic model to conform to this updated recommendation with a C-factor of 100 for the Sudden Valley portion of the South shore water system. We re-ran the hydraulic model to get fire flow results for LWWSD’s use. These fire flow results are included in



Attachment 2 of this memo, and these should replace the results in Table E-2 of the current LWWSD Water System Plan (Appendix E).

Attachments:

- Attachment 1: Technical Memorandum – LWWSD South Shore Fire Flow Analysis, May 2, 2018
- Attachment 2: Updated fire flow hydraulic model results (these replace WSP Appendix E, Table E-2)



## MEMORANDUM

---

TO: LWWS – Bill Hunter, PE

FROM: Brian Smith, PE and Melanie Mankamy, PE

SUBJECT: LWWS South Shore Fire Flow Analysis

DATE: May 2, 2018

---

## Introduction

The recently submitted 2017 LWWS Water System Plan indicated in Appendix E that there may be some hydrants in the system that cannot provide the required 500 gpm under Maximum Day Demand (MDD) while maintaining 20 psi pressure throughout the system. This evaluation analyzes the situation in further detail and presents potential projects to address specific issues.

The LWWS South Shore system pressure is provided by gravity from water storage reservoirs (with two exceptions of small closed pressure zones fed by booster stations). In the Sudden Valley area, there are some services and hydrants near the storage reservoirs that have pressures below the required minimum pressures because of their proximity to the reservoirs, as explained in Appendix E of the WSP. This complicates the analysis of available fire flow rates to the system because some junctions are near or below the required 20 psi under MDD without fire flow demand.

The fire flow analysis results shown in Table E-2 indicated 32 junctions at which available fire flow was less than 500 gpm to maintain 20 psi throughout the system. The analysis shown there ignored junctions near the reservoirs that started with pressures below 20 psi.

## Impact of Flowing 500 GPM

In order to assess the real impact to pressures throughout the water system under 500 gpm fire flow, this investigation assesses worst-case hydrants on a case-by-case basis and the lowest pressure junctions are analyzed. To provide a baseline, Table 1 shows junction pressures under MDD with no fireflow, ordered from lowest pressure to highest pressure. Only the first page of the model results are shown because the other 12 pages of results are not of interest to

this analysis. Table 1 shows that three of the junctions have pressures below 20 psi without fire flow (J1288, J203, J1540). J1288 and J203 are near the Division 22 reservoirs, and J1540 is near the Division 7 reservoir. The map in Figure 1 depicts these locations and all locations of interest in the current investigation.

Because each of these junctions have static pressures less than 20 psi, they were not included in the analysis in Appendix E of the WSP. The automated fire flow analysis of the model was not able to compute fire flows based on these junctions limiting because they began below 20 psi.

### *Hydrants at Bases of Reservoirs*

In order to see the impact to pressure that a fire flow event of 500 gpm would have at the base of each of the three reservoirs, the fire flow at these locations was manually entered into the model. Results can be seen in Tables 2A, 2B, and 2C. These Tables show that the first hydrant at the base of each of the reservoirs (J203, J1072, and J482) can provide 500 gpm with very little impact to system pressures. There are a few junctions that are below 20 psi, but the maximum decrease in pressure as compared to Table 1 is less than 1.5 psi at any of the junctions. So this impact is negligible and we can say that 500 gpm is available at each of these hydrants.

### *3 Other Hydrants*

As explained in Appendix E of the WSP, there are three other hydrants in the zone fed by gravity from Division 22 that have potential issues. The first is J1822FH, a fire hydrant at the end of Kinglet Ct. It is high in elevation and at the end of a non-looped portion of 6-inch pipe. Table 3A shows the fire flow results if the model is forced at 500 gpm at this location. As indicated by the negative pressure, this hydrant cannot provide 500 gpm.

A second hydrant with an issue is J1428. Table 3B shows junction pressures if the flow rate at this hydrant is 500 gpm. System pressures are decreased and a couple are brought from above 20 psi to below 20 psi, but the lowest system pressure is 8.02 psi, so this does not depressurize the water system. In Table E-2 of the WSP, most of the 32 hydrants that were limited to less than 500 gpm were limited by J1428. In all of those scenarios, the pressure at J1428 would be

brought below 20 psi at 500 gpm, but the pressure at all junctions would be higher than the worst-case scenario shown in Table 3B.

J1914 is the third hydrant with an issue. If it provides 500 gpm, junction pressures are shown in Table 3C. System pressures are decreased about the same amount as the scenario shown in Table 3B.

### **Potential Projects to Address Issues**

As described previously, there are three areas where 500 gpm cannot be provided without significant pressure loss in the system. Potential methods of addressing each of these are discussed below.

#### *J1822FH*

For J1822FH (hydrant on Kinglet), a simple alternative would be to leave the hydrant as-is and either label the hydrant in a way to explain that it cannot provide 500 gpm or install some sort of orifice plates at each of the ports to limit flow so that it does not depressurize the system locally. Another simple alternative would be to remove this hydrant. The hydrant on Kinglet near the intersection of Kinglet and Sudden Valley Drive is approximately 600 ft from the farthest parcels at the end of Kinglet, so even with the J1822FH hydrant removed, this area would be in compliance with the District's standard hydrant spacing of 600 ft.

A second option could be to add an 8 inch pipe from the Division 22 reservoirs directly to this hydrant to create a loop. This would require a new easement and roughly 350 ft of 8 inch pipe, but would result in 500 gpm being available at J1822FH in a similar manner to the other hydrants at the bases of the reservoirs. Junction pressures for this scenario are shown in Table 3A-1.


#### *J1428 and J1914*

The reason these two junctions (hydrants) are currently problems is due to the newly-adjusted C factor for all pipes in Sudden Valley. The calibration effort described in the WSP determined that a C factor of 70 was appropriate for the limited areas where flow testing occurred. But

## ATTACHMENT 1 - 2018 MEMO

pipes in the vicinity of Basinview and Highwood were not tested. It is possible that a C factor of 70 is not appropriate for these pipes. If the C factor in these vicinities is re-assessed and found to be 95 or greater, they will be capable of providing 500 gpm at 20 psi. Results for these scenarios are shown in Tables 3B-1 and 3C-1.

If the C factor is assessed and found to be less than 95, there are segments of existing pipe near each of these hydrants that could be replaced with new 8-inch pipe that would solve the pressure issue. These would be on the order of a couple hundred feet of new 8-inch pipe for each.



**Legend**

- Whatcom\_County\_Parks
- Whatcom\_County\_Reconveyance
- City\_of\_Bellingham
- Whatcom\_Land\_Trust

DATE	3/12/2018	SHEET	1
SCALE	As Shown	OF	1
JOB NUMBER	2016-096		

LAKE WHATCOM WATER AND SEWER DISTRICT  
 WASHINGTON  
 WHATCOM COUNTY

FIGURE 1 – SUDDEN VALLEY FIRE FLOW

Coordinate System:  
 State Plane Washington North  
 North American Datum 1983

Data Source:  
 City of Bellingham Public Works Dept.,  
 Whatcom County Planning & Assessor

WILSON ENGINEERING, LLC  
 805 DUPONT STREET  
 BELLINGHAM, WA 98225  
 (360) 733-6100 FAX (360) 647-9061  
 www.wilsonengineering.com



## ATTACHMENT 1 - 2018 MEMO

Table 1

Junction pressures (MDD, transmission pumps off, no fireflow)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	825.48	11.47
2	<input type="checkbox"/>	J203	0.00	800.00	827.30	11.83
3	<input type="checkbox"/>	J1540	0.00	668.00	695.80	12.05
4	<input type="checkbox"/>	J1072	2.90	1,003.00	1,050.05	20.39
5	<input type="checkbox"/>	J1822FH	0.00	778.00	825.48	20.57
6	<input type="checkbox"/>	J1847	0.00	780.00	828.14	20.86
7	<input type="checkbox"/>	J482	0.85	643.63	695.65	22.54
8	<input type="checkbox"/>	J768	0.49	771.38	826.43	23.85
9	<input type="checkbox"/>	J602	0.24	770.35	826.43	24.30
10	<input type="checkbox"/>	J54	1.33	763.82	826.46	27.14
11	<input type="checkbox"/>	J1896	0.00	621.00	685.16	27.80
12	<input type="checkbox"/>	J356	4.23	624.96	695.57	30.60
13	<input type="checkbox"/>	J1428	1.09	748.96	821.07	31.25
14	<input type="checkbox"/>	J566	5.82	613.00	685.14	31.26
15	<input type="checkbox"/>	J276	2.78	747.08	820.98	32.02
16	<input type="checkbox"/>	J592	1.69	745.84	821.00	32.57
17	<input type="checkbox"/>	J1914	0.85	749.04	824.47	32.68
18	<input type="checkbox"/>	J590	0.96	742.98	821.00	33.80
19	<input type="checkbox"/>	J1620	0.00	824.81	903.38	34.05
20	<input type="checkbox"/>	J502	2.29	736.59	821.09	36.61
21	<input type="checkbox"/>	J1845	0.00	600.00	685.11	36.88
22	<input type="checkbox"/>	J912	2.42	740.34	825.93	37.09
23	<input type="checkbox"/>	J1900	2.90	470.00	556.94	37.67
24	<input type="checkbox"/>	J1464	4.70	597.00	685.09	38.17
25	<input type="checkbox"/>	J1054	3.14	605.35	694.61	38.68
26	<input type="checkbox"/>	J1494	1.09	730.96	820.98	39.01
27	<input type="checkbox"/>	J104	0.00	811.31	903.38	39.90
28	<input type="checkbox"/>	J1394	2.42	726.45	821.78	41.31
29	<input type="checkbox"/>	J1920	2.90	804.37	903.37	42.90
30	<input type="checkbox"/>	J882	1.69	625.79	725.40	43.16
31	<input type="checkbox"/>	J56	1.21	726.07	826.03	43.31
32	<input type="checkbox"/>	J1482	0.00	625.06	725.41	43.48
33	<input type="checkbox"/>	J1843	1.34	584.00	685.10	43.81
34	<input type="checkbox"/>	J1272	0.00	797.55	898.74	43.85
35	<input type="checkbox"/>	J1438	1.21	722.99	824.49	43.98
36	<input type="checkbox"/>	J704	3.14	723.58	825.48	44.15
37	<input type="checkbox"/>	J102	3.50	801.05	903.38	44.34
38	<input type="checkbox"/>	J580	1.81	482.57	586.99	45.25
39	<input type="checkbox"/>	J201	0.51	580.00	684.78	45.40
40	<input type="checkbox"/>	J1882	0.67	580.00	684.82	45.42
41	<input type="checkbox"/>	J448	0.00	480.78	586.46	45.79
42	<input type="checkbox"/>	J1086	0.00	477.58	584.45	46.30
43	<input type="checkbox"/>	J1924	1.81	712.03	822.21	47.74
44	<input type="checkbox"/>	J1472	4.11	446.29	556.94	47.95
45	<input type="checkbox"/>	J1004	0.00	611.15	721.84	47.96
46	<input type="checkbox"/>	J1618	3.87	472.94	584.45	48.32
47	<input type="checkbox"/>	J1672	0.00	677.35	789.85	48.75
48	<input type="checkbox"/>	J185	0.00	572.00	685.01	48.97
49	<input type="checkbox"/>	J1052	0.45	571.00	685.01	49.40
50	<input type="checkbox"/>	J798	0.49	711.04	825.14	49.44

ATTACHMENT 1 - 2018 MEMO

Table 2A

Junction pressures (MDD, transmission pumps off, 500 gpm at J203 Div 22)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	823.14	10.46
2	<input type="checkbox"/>	J203	500.00	800.00	824.96	10.81
3	<input type="checkbox"/>	J1540	0.00	668.00	695.80	12.05
4	<input type="checkbox"/>	J1822FH	0.00	778.00	823.14	19.56
5	<input type="checkbox"/>	J1072	2.90	1,003.00	1,050.05	20.39
6	<input type="checkbox"/>	J1847	0.00	780.00	828.11	20.85
7	<input type="checkbox"/>	J482	0.85	643.63	695.65	22.54
8	<input type="checkbox"/>	J768	0.49	771.38	824.09	22.84
9	<input type="checkbox"/>	J602	0.24	770.35	824.09	23.28
10	<input type="checkbox"/>	J54	1.33	763.82	824.12	26.13
11	<input type="checkbox"/>	J1896	0.00	621.00	685.16	27.80
12	<input type="checkbox"/>	J1428	1.09	748.96	818.73	30.23
13	<input type="checkbox"/>	J356	4.23	624.96	695.57	30.60
14	<input type="checkbox"/>	J276	2.78	747.08	818.63	31.00
15	<input type="checkbox"/>	J566	5.82	613.00	685.14	31.26
16	<input type="checkbox"/>	J592	1.69	745.84	818.66	31.55
17	<input type="checkbox"/>	J1914	0.85	749.04	822.13	31.67
18	<input type="checkbox"/>	J590	0.96	742.98	818.65	32.79
19	<input type="checkbox"/>	J1620	0.00	824.81	903.38	34.05
20	<input type="checkbox"/>	J502	2.29	736.59	818.74	35.60
21	<input type="checkbox"/>	J912	2.42	740.34	823.59	36.07
22	<input type="checkbox"/>	J1845	0.00	600.00	685.11	36.88
23	<input type="checkbox"/>	J1900	2.90	470.00	556.94	37.67
24	<input type="checkbox"/>	J1494	1.09	730.96	818.64	37.99
25	<input type="checkbox"/>	J1464	4.70	597.00	685.09	38.17
26	<input type="checkbox"/>	J1054	3.14	605.35	694.61	38.68
27	<input type="checkbox"/>	J104	0.00	811.31	903.38	39.90
28	<input type="checkbox"/>	J1394	2.42	726.45	819.44	40.29
29	<input type="checkbox"/>	J56	1.21	726.07	823.69	42.30
30	<input type="checkbox"/>	J1920	2.90	804.37	903.37	42.90
31	<input type="checkbox"/>	J1438	1.21	722.99	822.15	42.96
32	<input type="checkbox"/>	J704	3.14	723.58	823.14	43.14
33	<input type="checkbox"/>	J882	1.69	625.79	725.40	43.16
34	<input type="checkbox"/>	J1482	0.00	625.06	725.41	43.48
35	<input type="checkbox"/>	J1843	1.34	584.00	685.10	43.81
36	<input type="checkbox"/>	J1272	0.00	797.55	898.74	43.85
37	<input type="checkbox"/>	J102	3.50	801.05	903.38	44.34
38	<input type="checkbox"/>	J580	1.81	482.57	586.99	45.25
39	<input type="checkbox"/>	J201	0.51	580.00	684.78	45.40
40	<input type="checkbox"/>	J1882	0.67	580.00	684.82	45.42
41	<input type="checkbox"/>	J448	0.00	480.78	586.46	45.79
42	<input type="checkbox"/>	J1086	0.00	477.58	584.45	46.30
43	<input type="checkbox"/>	J1924	1.81	712.03	819.86	46.72
44	<input type="checkbox"/>	J1472	4.11	446.29	556.94	47.95
45	<input type="checkbox"/>	J1004	0.00	611.15	721.84	47.96
46	<input type="checkbox"/>	J1618	3.87	472.94	584.45	48.32
47	<input type="checkbox"/>	J798	0.49	711.04	822.79	48.42
48	<input type="checkbox"/>	J1672	0.00	677.35	789.85	48.75
49	<input type="checkbox"/>	J185	0.00	572.00	685.01	48.97
50	<input type="checkbox"/>	J1384	1.21	707.63	820.78	49.03



ATTACHMENT 1 - 2018 MEMO

Table 2B

Junction pressures (MDD, transmission pumps off, 500 gpm at J1072 Div 30)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	825.48	11.47
2	<input type="checkbox"/>	J203	0.00	800.00	827.30	11.83
3	<input type="checkbox"/>	J1540	0.00	668.00	695.80	12.05
4	<input type="checkbox"/>	J1072	502.90	1,003.00	1,046.83	18.99
5	<input type="checkbox"/>	J1822FH	0.00	778.00	825.48	20.57
6	<input type="checkbox"/>	J1847	0.00	780.00	828.14	20.86
7	<input type="checkbox"/>	J482	0.85	643.63	695.65	22.54
8	<input type="checkbox"/>	J768	0.49	771.38	826.43	23.85
9	<input type="checkbox"/>	J602	0.24	770.35	826.43	24.30
10	<input type="checkbox"/>	J54	1.33	763.82	826.46	27.14
11	<input type="checkbox"/>	J1896	0.00	621.00	685.16	27.80
12	<input type="checkbox"/>	J356	4.23	624.96	695.57	30.60
13	<input type="checkbox"/>	J1428	1.09	748.96	821.07	31.25
14	<input type="checkbox"/>	J566	5.82	613.00	685.14	31.26
15	<input type="checkbox"/>	J276	2.78	747.08	820.98	32.02
16	<input type="checkbox"/>	J592	1.69	745.84	821.00	32.57
17	<input type="checkbox"/>	J1914	0.85	749.04	824.47	32.68
18	<input type="checkbox"/>	J590	0.96	742.98	821.00	33.80
19	<input type="checkbox"/>	J1620	0.00	824.81	903.38	34.05
20	<input type="checkbox"/>	J502	2.29	736.59	821.09	36.61
21	<input type="checkbox"/>	J1845	0.00	600.00	685.11	36.88
22	<input type="checkbox"/>	J912	2.42	740.34	825.93	37.09
23	<input type="checkbox"/>	J1900	2.90	470.00	556.94	37.67
24	<input type="checkbox"/>	J1464	4.70	597.00	685.09	38.17
25	<input type="checkbox"/>	J1054	3.14	605.35	694.61	38.68
26	<input type="checkbox"/>	J1494	1.09	730.96	820.98	39.01
27	<input type="checkbox"/>	J104	0.00	811.31	903.38	39.90
28	<input type="checkbox"/>	J1394	2.42	726.45	821.78	41.31
29	<input type="checkbox"/>	J1920	2.90	804.37	903.37	42.90
30	<input type="checkbox"/>	J882	1.69	625.79	725.40	43.16
31	<input type="checkbox"/>	J56	1.21	726.07	826.03	43.31
32	<input type="checkbox"/>	J1482	0.00	625.06	725.41	43.48
33	<input type="checkbox"/>	J1843	1.34	584.00	685.10	43.81
34	<input type="checkbox"/>	J1272	0.00	797.55	898.74	43.85
35	<input type="checkbox"/>	J1438	1.21	722.99	824.49	43.98
36	<input type="checkbox"/>	J704	3.14	723.58	825.48	44.15
37	<input type="checkbox"/>	J102	3.50	801.05	903.38	44.34
38	<input type="checkbox"/>	J580	1.81	482.57	586.99	45.25
39	<input type="checkbox"/>	J201	0.51	580.00	684.78	45.40
40	<input type="checkbox"/>	J1882	0.67	580.00	684.82	45.42
41	<input type="checkbox"/>	J448	0.00	480.78	586.46	45.79
42	<input type="checkbox"/>	J1086	0.00	477.58	584.45	46.30
43	<input type="checkbox"/>	J1924	1.81	712.03	822.21	47.74
44	<input type="checkbox"/>	J1472	4.11	446.29	556.94	47.95
45	<input type="checkbox"/>	J1004	0.00	611.15	721.84	47.96
46	<input type="checkbox"/>	J1618	3.87	472.94	584.45	48.32
47	<input type="checkbox"/>	J1672	0.00	677.35	789.85	48.75
48	<input type="checkbox"/>	J185	0.00	572.00	685.01	48.97
49	<input type="checkbox"/>	J1052	0.45	571.00	685.01	49.40
50	<input type="checkbox"/>	J798	0.49	711.04	825.14	49.44

ATTACHMENT 1 - 2018 MEMO

Table 2C

Junction pressures (MDD, transmission pumps off, 500 gpm at J482 Div 7)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	825.48	11.47
2	<input type="checkbox"/>	J1540	0.00	668.00	694.90	11.65
3	<input type="checkbox"/>	J203	0.00	800.00	827.30	11.83
4	<input type="checkbox"/>	J1072	2.90	1,003.00	1,050.05	20.39
5	<input type="checkbox"/>	J1822FH	0.00	778.00	825.48	20.57
6	<input type="checkbox"/>	J1847	0.00	780.00	828.14	20.86
7	<input type="checkbox"/>	J482	500.85	643.63	692.30	21.09
8	<input type="checkbox"/>	J768	0.49	771.38	826.43	23.85
9	<input type="checkbox"/>	J602	0.24	770.35	826.43	24.30
10	<input type="checkbox"/>	J54	1.33	763.82	826.46	27.14
11	<input type="checkbox"/>	J1896	0.00	621.00	685.16	27.80
12	<input type="checkbox"/>	J356	4.23	624.96	692.23	29.15
13	<input type="checkbox"/>	J1428	1.09	748.96	821.07	31.25
14	<input type="checkbox"/>	J566	5.82	613.00	685.14	31.26
15	<input type="checkbox"/>	J276	2.78	747.08	820.98	32.02
16	<input type="checkbox"/>	J592	1.69	745.84	821.00	32.57
17	<input type="checkbox"/>	J1914	0.85	749.04	824.47	32.68
18	<input type="checkbox"/>	J590	0.96	742.98	821.00	33.80
19	<input type="checkbox"/>	J1620	0.00	824.81	903.38	34.05
20	<input type="checkbox"/>	J502	2.29	736.59	821.09	36.61
21	<input type="checkbox"/>	J1845	0.00	600.00	685.11	36.88
22	<input type="checkbox"/>	J912	2.42	740.34	825.93	37.09
23	<input type="checkbox"/>	J1054	3.14	605.35	691.27	37.23
24	<input type="checkbox"/>	J1900	2.90	470.00	556.94	37.67
25	<input type="checkbox"/>	J1464	4.70	597.00	685.09	38.17
26	<input type="checkbox"/>	J1494	1.09	730.96	820.98	39.01
27	<input type="checkbox"/>	J104	0.00	811.31	903.38	39.90
28	<input type="checkbox"/>	J1394	2.42	726.45	821.78	41.31
29	<input type="checkbox"/>	J1920	2.90	804.37	903.37	42.90
30	<input type="checkbox"/>	J882	1.69	625.79	725.40	43.16
31	<input type="checkbox"/>	J56	1.21	726.07	826.03	43.31
32	<input type="checkbox"/>	J1482	0.00	625.06	725.41	43.48
33	<input type="checkbox"/>	J1843	1.34	584.00	685.10	43.81
34	<input type="checkbox"/>	J1272	0.00	797.55	898.74	43.85
35	<input type="checkbox"/>	J1438	1.21	722.99	824.49	43.98
36	<input type="checkbox"/>	J704	3.14	723.58	825.48	44.15
37	<input type="checkbox"/>	J102	3.50	801.05	903.38	44.34
38	<input type="checkbox"/>	J580	1.81	482.57	586.99	45.25
39	<input type="checkbox"/>	J201	0.51	580.00	684.78	45.40
40	<input type="checkbox"/>	J1882	0.67	580.00	684.82	45.42
41	<input type="checkbox"/>	J448	0.00	480.78	586.46	45.79
42	<input type="checkbox"/>	J1086	0.00	477.58	584.45	46.30
43	<input type="checkbox"/>	J1924	1.81	712.03	822.21	47.74
44	<input type="checkbox"/>	J1472	4.11	446.29	556.94	47.95
45	<input type="checkbox"/>	J1004	0.00	611.15	721.84	47.96
46	<input type="checkbox"/>	J1618	3.87	472.94	584.45	48.32
47	<input type="checkbox"/>	J1672	0.00	677.35	789.85	48.75
48	<input type="checkbox"/>	J185	0.00	572.00	685.01	48.97
49	<input type="checkbox"/>	J1052	0.45	571.00	685.01	49.40
50	<input type="checkbox"/>	J798	0.49	711.04	825.14	49.44

**ATTACHMENT 1 - 2018 MEMO**

**Table 3A**

Junction pressures (MDD, transmission pumps off, 500 gpm at J1822FH Kinglet)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	773.90	-10.87
2	<input type="checkbox"/>	J1822FH	500.00	778.00	773.90	-1.78
3	<input type="checkbox"/>	J203	0.00	800.00	824.96	10.81
4	<input type="checkbox"/>	J1540	0.00	668.00	695.80	12.05
5	<input type="checkbox"/>	J1072	2.90	1,003.00	1,050.05	20.39
6	<input type="checkbox"/>	J1847	0.00	780.00	828.11	20.85
7	<input type="checkbox"/>	J768	0.49	771.38	821.75	21.82
8	<input type="checkbox"/>	J602	0.24	770.35	821.75	22.27
9	<input type="checkbox"/>	J482	0.85	643.63	695.65	22.54
10	<input type="checkbox"/>	J54	1.33	763.82	821.80	25.13
11	<input type="checkbox"/>	J1428	1.09	748.96	813.04	27.77
12	<input type="checkbox"/>	J1896	0.00	621.00	685.16	27.80
13	<input type="checkbox"/>	J276	2.78	747.08	812.95	28.54
14	<input type="checkbox"/>	J592	1.69	745.84	812.98	29.09
15	<input type="checkbox"/>	J1914	0.85	749.04	816.37	29.17
16	<input type="checkbox"/>	J590	0.96	742.98	812.97	30.32
17	<input type="checkbox"/>	J356	4.23	624.96	695.57	30.60
18	<input type="checkbox"/>	J566	5.82	613.00	685.14	31.26
19	<input type="checkbox"/>	J502	2.29	736.59	813.06	33.14
20	<input type="checkbox"/>	J1620	0.00	824.81	903.38	34.05
21	<input type="checkbox"/>	J912	2.42	740.34	820.71	34.83
22	<input type="checkbox"/>	J1494	1.09	730.96	812.95	35.53
23	<input type="checkbox"/>	J1845	0.00	600.00	685.11	36.88
24	<input type="checkbox"/>	J1900	2.90	470.00	556.94	37.67
25	<input type="checkbox"/>	J1394	2.42	726.45	813.75	37.83
26	<input type="checkbox"/>	J1464	4.70	597.00	685.09	38.17
27	<input type="checkbox"/>	J1054	3.14	605.35	694.61	38.68
28	<input type="checkbox"/>	J104	0.00	811.31	903.38	39.90
29	<input type="checkbox"/>	J1438	1.21	722.99	816.38	40.47
30	<input type="checkbox"/>	J704	3.14	723.58	817.08	40.51
31	<input type="checkbox"/>	J56	1.21	726.07	820.09	40.74
32	<input type="checkbox"/>	J1920	2.90	804.37	903.37	42.90
33	<input type="checkbox"/>	J882	1.69	625.79	725.40	43.16
34	<input type="checkbox"/>	J1482	0.00	625.06	725.41	43.48
35	<input type="checkbox"/>	J1843	1.34	584.00	685.10	43.81
36	<input type="checkbox"/>	J1272	0.00	797.55	898.74	43.85
37	<input type="checkbox"/>	J1924	1.81	712.03	814.18	44.26
38	<input type="checkbox"/>	J102	3.50	801.05	903.38	44.34
39	<input type="checkbox"/>	J580	1.81	482.57	586.99	45.25
40	<input type="checkbox"/>	J201	0.51	580.00	684.78	45.40
41	<input type="checkbox"/>	J1882	0.67	580.00	684.82	45.42
42	<input type="checkbox"/>	J448	0.00	480.78	586.46	45.79
43	<input type="checkbox"/>	J798	0.49	711.04	816.80	45.82
44	<input type="checkbox"/>	J1086	0.00	477.58	584.45	46.30
45	<input type="checkbox"/>	J1384	1.21	707.63	815.23	46.63
46	<input type="checkbox"/>	J1386	1.45	707.43	815.20	46.70
47	<input type="checkbox"/>	J1334	3.38	706.64	816.37	47.54
48	<input type="checkbox"/>	J604	0.49	710.12	820.72	47.93
49	<input type="checkbox"/>	J1472	4.11	446.29	556.94	47.95
50	<input type="checkbox"/>	J1004	0.00	611.15	721.84	47.96

ATTACHMENT 1 - 2018 MEMO

Table 3B

Junction pressures (MDD, transmission pumps off, 500 gpm at J1428 Basinview)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	817.51	8.02
2	<input type="checkbox"/>	J1428	501.09	748.96	770.17	9.19
3	<input type="checkbox"/>	J203	0.00	800.00	824.96	10.81
4	<input type="checkbox"/>	J1540	0.00	668.00	695.80	12.05
5	<input type="checkbox"/>	J1822FH	0.00	778.00	817.51	17.12
6	<input type="checkbox"/>	J592	1.69	745.84	787.00	17.83
7	<input type="checkbox"/>	J276	2.78	747.08	789.72	18.47
8	<input type="checkbox"/>	J590	0.96	742.98	789.75	20.27
9	<input type="checkbox"/>	J1072	2.90	1,003.00	1,050.05	20.39
10	<input type="checkbox"/>	J1847	0.00	780.00	828.11	20.85
11	<input type="checkbox"/>	J768	0.49	771.38	821.74	21.82
12	<input type="checkbox"/>	J602	0.24	770.35	821.73	22.26
13	<input type="checkbox"/>	J482	0.85	643.63	695.65	22.54
14	<input type="checkbox"/>	J502	2.29	736.59	791.56	23.82
15	<input type="checkbox"/>	J54	1.33	763.82	821.80	25.13
16	<input type="checkbox"/>	J1494	1.09	730.96	789.12	25.20
17	<input type="checkbox"/>	J1896	0.00	621.00	685.16	27.80
18	<input type="checkbox"/>	J1914	0.85	749.04	813.58	27.96
19	<input type="checkbox"/>	J1394	2.42	726.45	796.40	30.31
20	<input type="checkbox"/>	J356	4.23	624.96	695.57	30.60
21	<input type="checkbox"/>	J566	5.82	613.00	685.14	31.26
22	<input type="checkbox"/>	J1620	0.00	824.81	903.38	34.05
23	<input type="checkbox"/>	J912	2.42	740.34	820.45	34.71
24	<input type="checkbox"/>	J1845	0.00	600.00	685.11	36.88
25	<input type="checkbox"/>	J1900	2.90	470.00	556.94	37.67
26	<input type="checkbox"/>	J1924	1.81	712.03	799.22	37.78
27	<input type="checkbox"/>	J1464	4.70	597.00	685.09	38.17
28	<input type="checkbox"/>	J1054	3.14	605.35	694.61	38.68
29	<input type="checkbox"/>	J1438	1.21	722.99	813.63	39.28
30	<input type="checkbox"/>	J104	0.00	811.31	903.38	39.90
31	<input type="checkbox"/>	J704	3.14	723.58	817.51	40.70
32	<input type="checkbox"/>	J56	1.21	726.07	820.12	40.75
33	<input type="checkbox"/>	J1386	1.45	707.43	805.96	42.70
34	<input type="checkbox"/>	J1384	1.21	707.63	806.17	42.70
35	<input type="checkbox"/>	J1920	2.90	804.37	903.37	42.90
36	<input type="checkbox"/>	J882	1.69	625.79	725.40	43.16
37	<input type="checkbox"/>	J1482	0.00	625.06	725.41	43.48
38	<input type="checkbox"/>	J1843	1.34	584.00	685.10	43.81
39	<input type="checkbox"/>	J1272	0.00	797.55	898.74	43.85
40	<input type="checkbox"/>	J102	3.50	801.05	903.38	44.34
41	<input type="checkbox"/>	J274	4.47	685.47	789.50	45.07
42	<input type="checkbox"/>	J580	1.81	482.57	586.99	45.25
43	<input type="checkbox"/>	J201	0.51	580.00	684.78	45.40
44	<input type="checkbox"/>	J798	0.49	711.04	815.86	45.42
45	<input type="checkbox"/>	J1882	0.67	580.00	684.82	45.42
46	<input type="checkbox"/>	J1442	2.05	684.18	789.30	45.55
47	<input type="checkbox"/>	J448	0.00	480.78	586.46	45.79
48	<input type="checkbox"/>	J1086	0.00	477.58	584.45	46.30
49	<input type="checkbox"/>	J1334	3.38	706.64	813.54	46.32
50	<input type="checkbox"/>	J604	0.49	710.12	820.46	47.81

ATTACHMENT 1 - 2018 MEMO

Table 3C

Junction pressures (MDD, transmission pumps off, 500 gpm at J1914 Highwood)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	817.52	8.03
2	<input type="checkbox"/>	J203	0.00	800.00	824.96	10.81
3	<input type="checkbox"/>	J1540	0.00	668.00	695.80	12.05
4	<input type="checkbox"/>	J1914	500.85	749.04	778.27	12.67
5	<input type="checkbox"/>	J1822FH	0.00	778.00	817.52	17.13
6	<input type="checkbox"/>	J1072	2.90	1,003.00	1,050.05	20.39
7	<input type="checkbox"/>	J1847	0.00	780.00	828.11	20.85
8	<input type="checkbox"/>	J768	0.49	771.38	821.74	21.82
9	<input type="checkbox"/>	J602	0.24	770.35	821.73	22.26
10	<input type="checkbox"/>	J482	0.85	643.63	695.65	22.54
11	<input type="checkbox"/>	J54	1.33	763.82	821.80	25.13
12	<input type="checkbox"/>	J1428	1.09	748.96	808.36	25.74
13	<input type="checkbox"/>	J276	2.78	747.08	808.27	26.51
14	<input type="checkbox"/>	J592	1.69	745.84	808.29	27.06
15	<input type="checkbox"/>	J1896	0.00	621.00	685.16	27.80
16	<input type="checkbox"/>	J590	0.96	742.98	808.29	28.30
17	<input type="checkbox"/>	J356	4.23	624.96	695.57	30.60
18	<input type="checkbox"/>	J502	2.29	736.59	808.38	31.11
19	<input type="checkbox"/>	J566	5.82	613.00	685.14	31.26
20	<input type="checkbox"/>	J1438	1.21	722.99	798.99	32.93
21	<input type="checkbox"/>	J1494	1.09	730.96	808.27	33.50
22	<input type="checkbox"/>	J1620	0.00	824.81	903.38	34.05
23	<input type="checkbox"/>	J912	2.42	740.34	820.43	34.70
24	<input type="checkbox"/>	J1394	2.42	726.45	809.07	35.80
25	<input type="checkbox"/>	J1845	0.00	600.00	685.11	36.88
26	<input type="checkbox"/>	J1900	2.90	470.00	556.94	37.67
27	<input type="checkbox"/>	J1464	4.70	597.00	685.09	38.17
28	<input type="checkbox"/>	J1054	3.14	605.35	694.61	38.68
29	<input type="checkbox"/>	J104	0.00	811.31	903.38	39.90
30	<input type="checkbox"/>	J704	3.14	723.58	817.52	40.70
31	<input type="checkbox"/>	J56	1.21	726.07	820.12	40.75
32	<input type="checkbox"/>	J1334	3.38	706.64	801.67	41.17
33	<input type="checkbox"/>	J1924	1.81	712.03	809.50	42.23
34	<input type="checkbox"/>	J1920	2.90	804.37	903.37	42.90
35	<input type="checkbox"/>	J882	1.69	625.79	725.40	43.16
36	<input type="checkbox"/>	J1482	0.00	625.06	725.41	43.48
37	<input type="checkbox"/>	J1843	1.34	584.00	685.10	43.81
38	<input type="checkbox"/>	J1272	0.00	797.55	898.74	43.85
39	<input type="checkbox"/>	J1386	1.45	707.43	809.41	44.19
40	<input type="checkbox"/>	J1384	1.21	707.63	809.90	44.32
41	<input type="checkbox"/>	J102	3.50	801.05	903.38	44.34
42	<input type="checkbox"/>	J1410	2.54	700.54	804.65	45.11
43	<input type="checkbox"/>	J580	1.81	482.57	586.99	45.25
44	<input type="checkbox"/>	J201	0.51	580.00	684.78	45.40
45	<input type="checkbox"/>	J1882	0.67	580.00	684.82	45.42
46	<input type="checkbox"/>	J798	0.49	711.04	815.89	45.43
47	<input type="checkbox"/>	J448	0.00	480.78	586.46	45.79
48	<input type="checkbox"/>	J1086	0.00	477.58	584.45	46.30
49	<input type="checkbox"/>	J1434	2.65	699.30	808.18	47.18
50	<input type="checkbox"/>	J604	0.49	710.12	820.45	47.81

**ATTACHMENT 1 - 2018 MEMO**

**Table 3A-1**

Junction pressures (MDD, transmission pumps off, 500 gpm at J1822FH Kinglet, new 8-inch pipe loop)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	826.11	11.75
2	<input type="checkbox"/>	J203	0.00	800.00	827.38	11.86
3	<input type="checkbox"/>	J1540	0.00	668.00	695.80	12.05
4	<input type="checkbox"/>	J1072	2.90	1,003.00	1,050.05	20.39
5	<input type="checkbox"/>	J1847	0.00	780.00	828.11	20.85
6	<input type="checkbox"/>	J1822FH	500.00	778.00	826.11	20.85
7	<input type="checkbox"/>	J482	0.85	643.63	695.65	22.54
8	<input type="checkbox"/>	J768	0.49	771.38	826.62	23.93
9	<input type="checkbox"/>	J602	0.24	770.35	826.62	24.38
10	<input type="checkbox"/>	J54	1.33	763.82	826.64	27.22
11	<input type="checkbox"/>	J1896	0.00	621.00	685.16	27.80
12	<input type="checkbox"/>	J356	4.23	624.96	695.57	30.60
13	<input type="checkbox"/>	J566	5.82	613.00	685.14	31.26
14	<input type="checkbox"/>	J1428	1.09	748.96	821.39	31.38
15	<input type="checkbox"/>	J276	2.78	747.08	821.30	32.16
16	<input type="checkbox"/>	J592	1.69	745.84	821.32	32.70
17	<input type="checkbox"/>	J1914	0.85	749.04	824.80	32.82
18	<input type="checkbox"/>	J590	0.96	742.98	821.31	33.94
19	<input type="checkbox"/>	J1620	0.00	824.81	903.38	34.05
20	<input type="checkbox"/>	J502	2.29	736.59	821.41	36.75
21	<input type="checkbox"/>	J1845	0.00	600.00	685.11	36.88
22	<input type="checkbox"/>	J912	2.42	740.34	826.14	37.18
23	<input type="checkbox"/>	J1900	2.90	470.00	556.94	37.67
24	<input type="checkbox"/>	J1464	4.70	597.00	685.09	38.17
25	<input type="checkbox"/>	J1054	3.14	605.35	694.61	38.68
26	<input type="checkbox"/>	J1494	1.09	730.96	821.30	39.14
27	<input type="checkbox"/>	J104	0.00	811.31	903.38	39.90
28	<input type="checkbox"/>	J1394	2.42	726.45	822.10	41.45
29	<input type="checkbox"/>	J1920	2.90	804.37	903.37	42.90
30	<input type="checkbox"/>	J882	1.69	625.79	725.40	43.16
31	<input type="checkbox"/>	J56	1.21	726.07	826.27	43.42
32	<input type="checkbox"/>	J1482	0.00	625.06	725.41	43.48
33	<input type="checkbox"/>	J1843	1.34	584.00	685.10	43.81
34	<input type="checkbox"/>	J1272	0.00	797.55	898.74	43.85
35	<input type="checkbox"/>	J1438	1.21	722.99	824.81	44.12
36	<input type="checkbox"/>	J704	3.14	723.58	825.82	44.30
37	<input type="checkbox"/>	J102	3.50	801.05	903.38	44.34
38	<input type="checkbox"/>	J580	1.81	482.57	586.99	45.25
39	<input type="checkbox"/>	J201	0.51	580.00	684.78	45.40
40	<input type="checkbox"/>	J1882	0.67	580.00	684.82	45.42
41	<input type="checkbox"/>	J448	0.00	480.78	586.46	45.79
42	<input type="checkbox"/>	J1086	0.00	477.58	584.45	46.30
43	<input type="checkbox"/>	J1924	1.81	712.03	822.53	47.88
44	<input type="checkbox"/>	J1472	4.11	446.29	556.94	47.95
45	<input type="checkbox"/>	J1004	0.00	611.15	721.84	47.96
46	<input type="checkbox"/>	J1618	3.87	472.94	584.45	48.32
47	<input type="checkbox"/>	J1672	0.00	677.35	789.85	48.75
48	<input type="checkbox"/>	J185	0.00	572.00	685.01	48.97
49	<input type="checkbox"/>	J1052	0.45	571.00	685.01	49.40
50	<input type="checkbox"/>	J38	5.80	472.32	586.44	49.45

**ATTACHMENT 1 - 2018 MEMO**

**Table 3B-1**

Junction pressures (MDD, transmission pumps off, 500 gpm at J1428 Basinview, C = 95)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	821.97	9.96
2	<input type="checkbox"/>	J203	0.00	800.00	826.28	11.39
3	<input type="checkbox"/>	J1540	0.00	668.00	695.82	12.06
4	<input type="checkbox"/>	J1822FH	0.00	785.00	821.97	16.02
5	<input type="checkbox"/>	J1072	2.90	1,005.00	1,050.09	19.54
6	<input type="checkbox"/>	J1428	501.09	748.96	795.45	20.14
7	<input type="checkbox"/>	J1847	0.00	780.00	828.12	20.85
8	<input type="checkbox"/>	J482	0.85	643.63	695.74	22.58
9	<input type="checkbox"/>	J768	0.49	771.38	824.39	22.97
10	<input type="checkbox"/>	J602	0.24	770.35	824.39	23.41
11	<input type="checkbox"/>	J592	1.69	745.84	805.11	25.68
12	<input type="checkbox"/>	J276	2.78	747.08	806.74	25.85
13	<input type="checkbox"/>	J54	1.33	763.82	824.43	26.26
14	<input type="checkbox"/>	J590	0.96	742.98	806.76	27.63
15	<input type="checkbox"/>	J1896	0.00	621.00	685.14	27.79
16	<input type="checkbox"/>	J1914	0.85	749.04	819.73	30.63
17	<input type="checkbox"/>	J356	4.23	624.96	695.69	30.65
18	<input type="checkbox"/>	J502	2.29	736.59	807.70	30.82
19	<input type="checkbox"/>	J566	5.82	613.00	685.13	31.26
20	<input type="checkbox"/>	J1494	1.09	730.96	806.38	32.68
21	<input type="checkbox"/>	J1620	0.00	824.81	903.39	34.05
22	<input type="checkbox"/>	J912	2.42	740.34	823.58	36.07
23	<input type="checkbox"/>	J1394	2.42	726.45	810.47	36.40
24	<input type="checkbox"/>	J1845	0.00	600.00	685.09	36.87
25	<input type="checkbox"/>	J1900	2.90	470.00	556.95	37.67
26	<input type="checkbox"/>	J1464	4.70	597.00	685.06	38.16
27	<input type="checkbox"/>	J1054	3.14	605.35	695.14	38.91
28	<input type="checkbox"/>	J104	0.00	811.31	903.39	39.90
29	<input type="checkbox"/>	J1438	1.21	722.99	819.76	41.93
30	<input type="checkbox"/>	J56	1.21	726.07	823.44	42.19
31	<input type="checkbox"/>	J704	3.14	723.58	821.97	42.63
32	<input type="checkbox"/>	J1920	2.90	804.37	903.38	42.90
33	<input type="checkbox"/>	J1924	1.81	712.03	812.01	43.32
34	<input type="checkbox"/>	J1843	1.34	584.00	685.08	43.80
35	<input type="checkbox"/>	J1272	0.00	797.55	898.75	43.85
36	<input type="checkbox"/>	J102	3.50	801.05	903.39	44.34
37	<input type="checkbox"/>	J882	1.69	625.79	728.97	44.71
38	<input type="checkbox"/>	J1482	0.00	625.06	728.97	45.03
39	<input type="checkbox"/>	J580	1.81	482.57	587.01	45.26
40	<input type="checkbox"/>	J201	0.51	580.00	684.67	45.35
41	<input type="checkbox"/>	J1882	0.67	580.00	684.72	45.37
42	<input type="checkbox"/>	J448	0.00	480.78	586.71	45.90
43	<input type="checkbox"/>	J1086	0.00	477.58	585.55	46.78
44	<input type="checkbox"/>	J1384	1.21	707.63	815.68	46.82
45	<input type="checkbox"/>	J1386	1.45	707.43	815.55	46.85
46	<input type="checkbox"/>	J798	0.49	711.04	821.03	47.66
47	<input type="checkbox"/>	J1472	4.11	446.29	556.95	47.95
48	<input type="checkbox"/>	J1004	0.00	611.15	723.27	48.58
49	<input type="checkbox"/>	J1672	0.00	677.35	789.92	48.78
50	<input type="checkbox"/>	J1618	3.87	472.94	585.55	48.79

**ATTACHMENT 1 - 2018 MEMO**

**Table 3C-1**

Junction pressures (MDD, transmission pumps off, 500 gpm at J1914 Highwood, C=95)

		ID	Demand (gpm)	Elevation (ft)	Head (ft)	Pressure (psi)
1	<input type="checkbox"/>	J1288	0.00	799.00	821.98	9.96
2	<input type="checkbox"/>	J203	0.00	800.00	826.28	11.39
3	<input type="checkbox"/>	J1540	0.00	668.00	695.82	12.06
4	<input type="checkbox"/>	J1822FH	0.00	785.00	821.98	16.02
5	<input type="checkbox"/>	J1072	2.90	1,005.00	1,050.09	19.54
6	<input type="checkbox"/>	J1847	0.00	780.00	828.12	20.85
7	<input type="checkbox"/>	J1914	500.85	749.04	799.44	21.84
8	<input type="checkbox"/>	J482	0.85	643.63	695.74	22.58
9	<input type="checkbox"/>	J768	0.49	771.38	824.39	22.97
10	<input type="checkbox"/>	J602	0.24	770.35	824.39	23.41
11	<input type="checkbox"/>	J54	1.33	763.82	824.43	26.26
12	<input type="checkbox"/>	J1896	0.00	621.00	685.14	27.79
13	<input type="checkbox"/>	J1428	1.09	748.96	817.10	29.52
14	<input type="checkbox"/>	J276	2.78	747.08	817.05	30.32
15	<input type="checkbox"/>	J356	4.23	624.96	695.69	30.65
16	<input type="checkbox"/>	J592	1.69	745.84	817.06	30.86
17	<input type="checkbox"/>	J566	5.82	613.00	685.13	31.26
18	<input type="checkbox"/>	J590	0.96	742.98	817.06	32.10
19	<input type="checkbox"/>	J1620	0.00	824.81	903.39	34.05
20	<input type="checkbox"/>	J502	2.29	736.59	817.09	34.88
21	<input type="checkbox"/>	J912	2.42	740.34	823.57	36.07
22	<input type="checkbox"/>	J1845	0.00	600.00	685.09	36.87
23	<input type="checkbox"/>	J1494	1.09	730.96	817.05	37.30
24	<input type="checkbox"/>	J1900	2.90	470.00	556.95	37.67
25	<input type="checkbox"/>	J1464	4.70	597.00	685.06	38.16
26	<input type="checkbox"/>	J1438	1.21	722.99	811.35	38.29
27	<input type="checkbox"/>	J1054	3.14	605.35	695.14	38.91
28	<input type="checkbox"/>	J1394	2.42	726.45	817.48	39.44
29	<input type="checkbox"/>	J104	0.00	811.31	903.39	39.90
30	<input type="checkbox"/>	J56	1.21	726.07	823.44	42.19
31	<input type="checkbox"/>	J704	3.14	723.58	821.98	42.64
32	<input type="checkbox"/>	J1920	2.90	804.37	903.38	42.90
33	<input type="checkbox"/>	J1843	1.34	584.00	685.08	43.80
34	<input type="checkbox"/>	J1272	0.00	797.55	898.75	43.85
35	<input type="checkbox"/>	J102	3.50	801.05	903.39	44.34
36	<input type="checkbox"/>	J882	1.69	625.79	728.97	44.71
37	<input type="checkbox"/>	J1482	0.00	625.06	728.97	45.03
38	<input type="checkbox"/>	J580	1.81	482.57	587.01	45.26
39	<input type="checkbox"/>	J201	0.51	580.00	684.67	45.35
40	<input type="checkbox"/>	J1882	0.67	580.00	684.72	45.37
41	<input type="checkbox"/>	J1924	1.81	712.03	817.68	45.78
42	<input type="checkbox"/>	J448	0.00	480.78	586.71	45.90
43	<input type="checkbox"/>	J1334	3.38	706.64	812.92	46.05
44	<input type="checkbox"/>	J1086	0.00	477.58	585.55	46.78
45	<input type="checkbox"/>	J798	0.49	711.04	821.04	47.66
46	<input type="checkbox"/>	J1386	1.45	707.43	817.55	47.71
47	<input type="checkbox"/>	J1384	1.21	707.63	817.81	47.74
48	<input type="checkbox"/>	J1472	4.11	446.29	556.95	47.95
49	<input type="checkbox"/>	J1004	0.00	611.15	723.27	48.58
50	<input type="checkbox"/>	J1672	0.00	677.35	789.92	48.78



## Attachment 2: Updated Fire Flow Model Results

REPLACEMENT Table E-2: South Shore Fire Flow Model Results

		ID	Total Demand (gpm)	Hydrant Available Flow (gpm)	Critical Node ID for Design Run	Critical Node Pressure at Available Flow (psi)	Critical Node Pressure at Fire Demand (psi)	Critical Pressure for Design Run (psi)	Hydrant Design Flow (gpm)	Hydrant Pressure at Design Flow (psi)
1	<input type="checkbox"/>	J1428	501.09	569.72	J1428	20.00	22.53	20.00	569.72	20.00
2	<input type="checkbox"/>	J1914	500.85	601.54	J1914	20.00	23.82	20.00	601.52	20.24
3	<input type="checkbox"/>	J840	501.81	677.15	J840	20.00	32.43	20.00	677.15	20.01
4	<input type="checkbox"/>	J998	500.00	707.93	J998	20.00	57.86	20.00	707.93	20.35
5	<input type="checkbox"/>	J1272	500.00	712.36	J1272	20.00	31.39	20.00	712.36	20.16
6	<input type="checkbox"/>	J1442	752.05	727.73	J1442	20.00	17.54	20.00	727.73	20.00
7	<input type="checkbox"/>	J592	751.69	776.82	J1428	19.15	19.87	20.00	746.99	20.86
8	<input type="checkbox"/>	J900	500.00	843.54	J996	5.64	55.98	20.00	759.27	37.97
9	<input type="checkbox"/>	J996	503.98	763.26	J996	20.00	55.98	20.00	763.26	20.15
10	<input type="checkbox"/>	J1284	751.45	767.02	J1284	20.00	20.58	20.00	767.02	20.00
11	<input type="checkbox"/>	J1554	750.85	770.82	J1554	20.00	22.27	20.00	770.82	20.02
12	<input type="checkbox"/>	J1052	750.45	792.76	J1052	20.00	22.76	20.00	792.76	20.09
13	<input type="checkbox"/>	J980	750.67	1,127.11	J1052	-4.91	23.33	20.00	802.53	46.14
14	<input type="checkbox"/>	J276	752.78	817.86	J1428	19.79	21.42	20.00	809.79	20.22
15	<input type="checkbox"/>	J522	751.69	1,847.96	J1428	-6.14	21.48	20.00	811.02	55.87
16	<input type="checkbox"/>	J1994	751.93	2,129.39	J1428	-14.37	21.48	20.00	811.27	70.28
17	<input type="checkbox"/>	J1796	752.05	958.85	J1428	16.00	21.48	20.00	811.38	31.33
18	<input type="checkbox"/>	J558	752.78	1,112.49	J1428	11.36	21.48	20.00	812.11	49.74
19	<input type="checkbox"/>	J274	754.47	1,417.85	J1428	0.75	21.48	20.00	813.80	44.41
20	<input type="checkbox"/>	J222	502.42	889.95	J996	8.00	59.54	20.00	814.06	32.41
21	<input type="checkbox"/>	J532	752.65	1,334.09	J1428	4.02	21.64	20.00	819.20	38.68
22	<input type="checkbox"/>	J498	501.45	819.49	J498	20.00	41.93	20.00	819.22	20.49
23	<input type="checkbox"/>	J872	753.38	1,013.42	J1428	14.64	21.64	20.00	819.93	49.90
24	<input type="checkbox"/>	J1724	750.85	931.01	J1428	17.07	21.70	20.00	820.26	33.46
25	<input type="checkbox"/>	J1330	752.91	987.72	J1052	8.29	24.22	20.00	820.50	31.96
26	<input type="checkbox"/>	J1484	501.81	841.28	J1484	20.00	41.74	20.00	841.28	20.01
27	<input type="checkbox"/>	J788	752.42	1,214.45	J1428	10.41	22.15	20.00	843.17	40.90
28	<input type="checkbox"/>	J502	752.29	1,031.44	J1428	15.06	22.16	20.00	843.77	25.06
29	<input type="checkbox"/>	J1172	756.94	1,314.29	J1052	-15.10	25.74	20.00	853.48	55.25
30	<input type="checkbox"/>	J1438	751.21	1,197.80	J1914	8.92	22.83	20.00	856.92	31.40
31	<input type="checkbox"/>	J1460	751.45	858.96	J1460	20.00	27.56	20.00	858.95	20.00
32	<input type="checkbox"/>	J1482	500.00	901.24	J1482	20.00	35.78	20.00	901.22	20.02
33	<input type="checkbox"/>	J402	751.33	903.76	J402	20.00	35.04	20.00	903.76	20.15
34	<input type="checkbox"/>	J1334	753.38	1,438.29	J1914	4.32	24.29	20.00	934.16	37.17
35	<input type="checkbox"/>	J1394	752.42	1,349.03	J1428	10.12	24.10	20.00	954.08	29.90
36	<input type="checkbox"/>	J630	753.26	1,025.38	J1428	18.40	24.10	20.00	954.93	24.81
37	<input type="checkbox"/>	J1984	500.00	971.57	J1984	20.00	51.16	20.00	971.51	20.00
38	<input type="checkbox"/>	J1670	500.00	971.62	J1670	20.00	45.52	20.00	971.62	20.00
39	<input type="checkbox"/>	J410	750.00	1,459.30	J1428	6.74	24.95	20.00	971.94	52.08
40	<input type="checkbox"/>	J210	750.00	1,022.89	J1428	18.74	24.95	20.00	971.94	22.63
41	<input type="checkbox"/>	J1730	750.00	1,522.71	J1428	4.80	24.95	20.00	971.94	71.31
42	<input type="checkbox"/>	J408	750.00	1,287.54	J1428	11.58	24.95	20.00	971.95	34.96
43	<input type="checkbox"/>	J816	755.67	4,090.74	J1428	-54.24	24.19	20.00	984.04	111.31
44	<input type="checkbox"/>	J272	750.90	986.46	J272	20.00	36.17	20.00	986.46	20.19
45	<input type="checkbox"/>	J1480	501.45	1,007.25	J1480	20.00	43.44	20.00	1,007.17	20.35
46	<input type="checkbox"/>	J182	750.00	3,939.94	J1428	-44.90	24.29	20.00	1,009.65	97.64
47	<input type="checkbox"/>	J1246	500.00	1,017.62	J1246	20.00	56.31	20.00	1,017.56	20.22
48	<input type="checkbox"/>	J1924	751.81	1,667.47	J1428	3.81	25.05	20.00	1,021.19	36.22
49	<input type="checkbox"/>	J1548	750.00	1,659.19	J1428	7.97	24.63	20.00	1,030.02	49.05

## Attachment 2: Updated Fire Flow Model Results

REPLACEMENT Table E-2: South Shore Fire Flow Model Results

		ID	Total Demand (gpm)	Hydrant Available Flow (gpm)	Critical Node ID for Design Run	Critical Node Pressure at Available Flow (psi)	Critical Node Pressure at Fire Demand (psi)	Critical Pressure for Design Run (psi)	Hydrant Design Flow (gpm)	Hydrant Pressure at Design Flow (psi)
50	<input type="checkbox"/>	J1324	750.00	2,733.02	J1428	-11.42	24.63	20.00	1,030.02	74.21
51	<input type="checkbox"/>	J1946	750.00	1,337.61	J482	18.62	21.07	20.00	1,038.47	36.60
52	<input type="checkbox"/>	J464	750.73	1,562.12	J482	17.41	21.07	20.00	1,039.20	52.42
53	<input type="checkbox"/>	J482	750.85	1,039.31	J482	20.00	21.07	20.00	1,039.31	20.00
54	<input type="checkbox"/>	J580	751.81	2,641.14	J482	11.89	21.07	20.00	1,040.27	44.12
55	<input type="checkbox"/>	J1054	753.14	1,127.41	J482	19.63	21.07	20.00	1,041.61	22.38
56	<input type="checkbox"/>	J454	500.00	1,042.54	J454	20.00	61.78	20.00	1,042.51	20.17
57	<input type="checkbox"/>	J356	754.23	1,639.52	J482	16.97	21.07	20.00	1,042.70	25.80
58	<input type="checkbox"/>	J742	751.09	2,777.36	J482	11.66	21.07	20.00	1,043.02	53.58
59	<input type="checkbox"/>	J164	500.00	1,915.62	J1428	-2.78	30.36	20.00	1,043.08	58.01
60	<input type="checkbox"/>	J400	755.67	1,651.47	J482	16.91	21.07	20.00	1,044.14	54.47
61	<input type="checkbox"/>	J1716	500.00	1,569.91	J1428	6.35	30.40	20.00	1,047.27	62.87
62	<input type="checkbox"/>	J1590	500.00	1,401.09	J1428	10.67	30.38	20.00	1,050.09	36.72
63	<input type="checkbox"/>	J1042	751.69	2,844.23	J482	10.79	21.07	20.00	1,058.88	49.06
64	<input type="checkbox"/>	J1156	753.14	3,526.14	J1428	-29.88	25.06	20.00	1,062.30	83.60
65	<input type="checkbox"/>	J606	751.33	2,657.78	J482	12.46	21.07	20.00	1,065.41	67.15
66	<input type="checkbox"/>	J1358	503.50	1,579.06	J1428	6.97	30.44	20.00	1,069.64	68.98
67	<input type="checkbox"/>	J199	750.26	1,079.64	J199	20.00	38.29	20.00	1,079.64	20.00
68	<input type="checkbox"/>	J784	753.02	2,101.06	J1428	-5.91	25.84	20.00	1,088.77	46.26
69	<input type="checkbox"/>	J912	752.42	1,088.87	J912	20.00	28.62	20.00	1,088.87	20.00
70	<input type="checkbox"/>	J32	750.00	2,301.56	J482	14.15	21.07	20.00	1,089.04	63.64
71	<input type="checkbox"/>	J768	750.49	1,089.55	J768	20.00	22.04	20.00	1,089.55	20.00
72	<input type="checkbox"/>	J160	752.78	2,324.82	J482	13.98	21.07	20.00	1,100.62	64.76
73	<input type="checkbox"/>	J712	753.74	2,908.97	J1428	-13.22	25.60	20.00	1,100.71	86.63
74	<input type="checkbox"/>	J158	752.78	2,372.80	J482	13.76	21.07	20.00	1,102.07	65.68
75	<input type="checkbox"/>	J448	750.00	2,519.45	J482	12.92	21.11	20.00	1,103.56	41.27
76	<input type="checkbox"/>	J1556	751.21	1,108.18	J1556	20.00	49.41	20.00	1,108.16	20.83
77	<input type="checkbox"/>	J728	751.33	1,281.36	J912	14.74	28.94	20.00	1,109.90	29.11
78	<input type="checkbox"/>	J1732	500.00	2,138.45	J1428	-4.79	30.53	20.00	1,110.47	84.40
79	<input type="checkbox"/>	J730	751.45	1,112.65	J730	20.00	44.20	20.00	1,112.65	20.45
80	<input type="checkbox"/>	J538	751.21	2,702.89	J482	12.16	21.07	20.00	1,112.66	65.06
81	<input type="checkbox"/>	J832	500.00	1,113.89	J832	20.00	59.35	20.00	1,113.89	20.09
82	<input type="checkbox"/>	J1204	750.85	2,690.18	J482	12.54	21.14	20.00	1,118.64	58.03
83	<input type="checkbox"/>	J1434	752.65	1,807.76	J1914	1.92	26.76	20.00	1,119.01	40.20
84	<input type="checkbox"/>	J1112	751.33	2,768.10	J482	11.52	21.17	20.00	1,119.21	47.80
85	<input type="checkbox"/>	J1050	501.93	1,385.55	J1482	5.22	38.36	20.00	1,124.15	34.88
86	<input type="checkbox"/>	J426	502.42	1,480.74	J1482	-2.35	38.42	20.00	1,133.29	45.75
87	<input type="checkbox"/>	J252	502.78	1,389.93	J1482	5.47	38.42	20.00	1,133.66	37.98
88	<input type="checkbox"/>	J278	750.49	3,191.69	J482	9.63	21.20	20.00	1,134.30	63.34
89	<input type="checkbox"/>	J38	755.80	1,842.87	J482	16.73	21.19	20.00	1,135.49	36.71
90	<input type="checkbox"/>	J1030	751.57	2,938.32	J482	10.74	21.20	20.00	1,138.65	52.94
91	<input type="checkbox"/>	J1410	752.54	1,429.99	J1914	13.36	26.98	20.00	1,139.90	31.53
92	<input type="checkbox"/>	J250	502.05	1,552.36	J1482	-7.97	38.49	20.00	1,141.03	56.17
93	<input type="checkbox"/>	J1694	750.36	1,141.37	J1694	20.00	44.38	20.00	1,141.37	20.00
94	<input type="checkbox"/>	J806	501.57	1,493.19	J1482	-2.64	38.50	20.00	1,141.67	53.63
95	<input type="checkbox"/>	J82	502.54	1,444.18	J1482	1.46	38.50	20.00	1,143.14	53.04
96	<input type="checkbox"/>	J544	502.29	1,450.97	J1482	0.90	38.51	20.00	1,143.64	54.19
97	<input type="checkbox"/>	J1048	503.50	1,598.82	J1482	-11.98	38.50	20.00	1,144.55	61.90
98	<input type="checkbox"/>	J302	502.29	1,657.28	J1482	-17.51	38.52	20.00	1,145.07	70.35

## Attachment 2: Updated Fire Flow Model Results

REPLACEMENT Table E-2: South Shore Fire Flow Model Results

		ID	Total Demand (gpm)	Hydrant Available Flow (gpm)	Critical Node ID for Design Run	Critical Node Pressure at Available Flow (psi)	Critical Node Pressure at Fire Demand (psi)	Critical Pressure for Design Run (psi)	Hydrant Design Flow (gpm)	Hydrant Pressure at Design Flow (psi)
99	<input type="checkbox"/>	J1584	504.71	1,509.37	J1670	1.27	47.42	20.00	1,147.63	38.69
100	<input type="checkbox"/>	J324	502.65	1,533.78	J1482	-5.80	38.54	20.00	1,148.10	56.89
101	<input type="checkbox"/>	J1174	501.33	1,427.56	J1482	3.14	38.55	20.00	1,148.39	50.93
102	<input type="checkbox"/>	J700	750.00	2,654.85	J482	12.43	21.25	20.00	1,149.96	94.19
103	<input type="checkbox"/>	J300	503.38	1,673.21	J1482	-18.57	38.55	20.00	1,150.36	73.23
104	<input type="checkbox"/>	J628	501.81	1,651.99	J1482	-16.53	38.57	20.00	1,151.34	72.43
105	<input type="checkbox"/>	J58	501.09	1,355.87	J1482	9.18	38.57	20.00	1,151.61	36.11
106	<input type="checkbox"/>	J698	751.69	3,075.09	J482	10.18	21.25	20.00	1,151.65	100.91
107	<input type="checkbox"/>	J1990	502.29	1,360.75	J1272	10.03	38.66	20.00	1,153.62	30.32
108	<input type="checkbox"/>	J36	751.69	3,296.80	J482	9.18	21.26	20.00	1,154.31	72.73
109	<input type="checkbox"/>	J1894	750.00	1,942.57	J482	16.28	21.26	20.00	1,154.34	71.66
110	<input type="checkbox"/>	J1892	750.00	3,203.24	J482	9.56	21.26	20.00	1,154.34	95.36
111	<input type="checkbox"/>	J598	501.21	1,368.51	J1482	8.51	38.63	20.00	1,158.14	41.43
112	<input type="checkbox"/>	J600	501.81	1,526.52	J1482	-4.39	38.65	20.00	1,160.38	57.53
113	<input type="checkbox"/>	J1064	750.73	1,614.81	J482	18.12	21.25	20.00	1,161.04	56.01
114	<input type="checkbox"/>	J1062	750.73	2,902.45	J482	11.65	21.25	20.00	1,161.04	76.07
115	<input type="checkbox"/>	J550	751.33	3,380.54	J482	8.70	21.28	20.00	1,163.74	76.76
116	<input type="checkbox"/>	J1982	502.05	1,203.96	J1984	17.48	54.74	20.00	1,167.62	22.07
117	<input type="checkbox"/>	J1238	752.24	1,173.24	J1238	20.00	65.34	20.00	1,173.23	20.69
118	<input type="checkbox"/>	J1704	501.69	1,449.30	J1482	2.77	38.73	20.00	1,173.86	50.72
119	<input type="checkbox"/>	J1384	751.21	1,185.30	J1384	20.00	37.30	20.00	1,185.30	20.02
120	<input type="checkbox"/>	J1364	500.00	1,186.21	J1364	20.00	54.31	20.00	1,186.21	20.09
121	<input type="checkbox"/>	J682	750.85	2,925.92	J482	11.80	21.31	20.00	1,187.85	84.34
122	<input type="checkbox"/>	J1708	500.85	1,568.10	J1482	-6.93	38.94	20.00	1,189.75	47.06
123	<input type="checkbox"/>	J868	753.14	4,179.37	J1428	-42.14	26.48	20.00	1,194.04	91.22
124	<input type="checkbox"/>	J1476	757.85	3,301.97	J482	9.51	21.35	20.00	1,198.83	69.07
125	<input type="checkbox"/>	J838	500.00	1,733.02	J840	-6.93	43.18	20.00	1,200.73	47.09
126	<input type="checkbox"/>	J1414	750.00	2,771.32	J482	12.85	21.34	20.00	1,201.15	79.04
127	<input type="checkbox"/>	J1232	751.79	1,201.73	J1232	20.00	38.48	20.00	1,201.73	20.01
128	<input type="checkbox"/>	J1002	751.33	1,206.58	J1002	20.00	51.52	20.00	1,206.57	20.00
129	<input type="checkbox"/>	J197	750.26	1,576.34	J199	-2.96	41.96	20.00	1,213.45	42.98
130	<input type="checkbox"/>	J1104	751.57	2,102.65	J482	16.31	21.37	20.00	1,215.96	63.78
131	<input type="checkbox"/>	J1310	500.00	1,221.27	J1310	20.00	49.64	20.00	1,221.18	20.00
132	<input type="checkbox"/>	J1386	751.45	1,664.47	J1428	11.66	26.96	20.00	1,225.05	33.01
133	<input type="checkbox"/>	J60	501.45	1,419.22	J1482	8.60	39.17	20.00	1,238.84	38.03
134	<input type="checkbox"/>	J1448	500.00	1,507.24	J1482	3.84	38.77	20.00	1,241.12	29.28
135	<input type="checkbox"/>	J858	500.00	2,419.89	J1482	-30.90	38.77	20.00	1,241.12	54.38
136	<input type="checkbox"/>	J304	501.69	1,248.13	J304	20.00	66.98	20.00	1,248.13	20.00
137	<input type="checkbox"/>	J1234	751.69	3,108.03	J1428	-16.08	27.39	20.00	1,249.69	59.05
138	<input type="checkbox"/>	J908	500.00	1,258.18	J908	20.00	59.56	20.00	1,258.18	20.01
139	<input type="checkbox"/>	J670	503.62	2,013.59	J1428	4.21	30.93	20.00	1,260.19	72.16
140	<input type="checkbox"/>	J1928	751.79	1,265.14	J1928	20.00	41.55	20.00	1,265.13	20.01
141	<input type="checkbox"/>	J1636	751.93	3,941.39	J1428	-32.29	27.05	20.00	1,267.12	74.29
142	<input type="checkbox"/>	J442	750.00	1,396.96	J1428	17.28	28.91	20.00	1,275.16	24.82
143	<input type="checkbox"/>	J1086	750.00	1,949.43	J1428	5.69	28.95	20.00	1,275.98	38.83
144	<input type="checkbox"/>	J328	750.00	1,543.78	J1428	13.73	28.98	20.00	1,276.92	33.36
145	<input type="checkbox"/>	J1616	750.00	1,831.06	J1428	7.70	29.05	20.00	1,278.50	51.08
146	<input type="checkbox"/>	J412	750.00	1,828.38	J1428	7.78	29.08	20.00	1,279.01	60.12
147	<input type="checkbox"/>	J726	750.00	1,888.22	J1428	6.72	29.11	20.00	1,279.50	55.34

## Attachment 2: Updated Fire Flow Model Results

REPLACEMENT Table E-2: South Shore Fire Flow Model Results

	ID	Total Demand (gpm)	Hydrant Available Flow (gpm)	Critical Node ID for Design Run	Critical Node Pressure at Available Flow (psi)	Critical Node Pressure at Fire Demand (psi)	Critical Pressure for Design Run (psi)	Hydrant Design Flow (gpm)	Hydrant Pressure at Design Flow (psi)
148	J1754	751.57	1,881.54	J1428	6.84	29.15	20.00	1,281.87	59.02
149	J414	753.87	1,841.03	J1428	7.58	29.05	20.00	1,282.26	50.82
150	J1536	751.93	1,625.03	J1428	11.94	29.18	20.00	1,282.66	31.58
151	J1298	753.87	1,877.64	J1428	6.94	29.11	20.00	1,283.34	53.46
152	J756	502.18	1,683.28	J840	2.22	43.88	20.00	1,287.77	40.60
153	J1534	752.90	2,085.71	J1428	3.79	29.45	20.00	1,289.69	43.91
154	J1106	751.57	1,295.55	J1106	20.00	86.45	20.00	1,295.53	21.63
155	J526	501.33	1,295.77	J526	20.00	57.49	20.00	1,295.78	20.09
156	J256	503.74	1,629.38	J1482	-5.39	39.86	20.00	1,297.24	46.21
157	J1236	752.65	3,393.19	J1428	-20.70	27.75	20.00	1,298.91	64.59
158	J1720	750.00	1,495.31	J1914	16.33	28.29	20.00	1,302.50	29.18
159	J1566	750.00	3,474.71	J482	9.86	21.52	20.00	1,306.82	98.54
160	J1998	750.00	2,417.21	J1428	-0.31	29.59	20.00	1,311.68	54.10
161	J620	752.18	2,474.65	J1428	-0.89	29.60	20.00	1,315.70	56.38
162	J116	754.26	1,865.12	J199	-13.36	43.99	20.00	1,316.15	53.38
163	J1256	500.00	1,475.34	J1482	8.65	39.89	20.00	1,316.98	33.02
164	J1058	750.67	1,322.10	J1058	20.00	53.47	20.00	1,322.11	20.64
165	J144	750.00	2,392.76	J1428	0.34	29.68	20.00	1,322.30	77.30
166	J142	751.33	2,282.22	J1428	1.61	29.69	20.00	1,323.81	73.80
167	J702	750.00	1,930.18	J1428	6.88	29.70	20.00	1,324.04	62.90
168	J1656	752.18	3,414.42	J1428	-19.92	27.41	20.00	1,324.28	49.08
169	J496	753.02	2,429.83	J1428	-0.03	29.69	20.00	1,326.02	79.58
170	J1662	500.00	1,792.99	J1482	-15.78	39.86	20.00	1,326.19	58.92
171	J760	500.00	1,462.57	J1428	17.30	32.45	20.00	1,334.36	34.48
172	J758	751.45	2,882.18	J1428	-5.31	29.80	20.00	1,335.67	96.18
173	J946	751.21	2,813.23	J1428	-4.49	29.80	20.00	1,335.74	69.21
174	J1544	753.02	2,370.03	J482	15.99	21.53	20.00	1,337.16	71.24
175	J1996	751.21	2,174.37	J1428	3.72	29.87	20.00	1,343.49	47.89
176	J1078	750.00	1,345.73	J1078	20.00	62.23	20.00	1,345.73	20.01
177	J268	750.36	2,894.04	J1428	-5.07	29.93	20.00	1,348.44	75.56
178	J1760	752.02	1,354.56	J1760	20.00	68.58	20.00	1,354.56	20.00
179	J318	500.00	1,383.04	J1482	18.80	39.88	20.00	1,365.23	23.49
180	J638	500.85	1,945.31	J1482	-22.26	39.88	20.00	1,366.08	68.48
181	J1750	751.34	1,471.93	J1232	15.55	41.34	20.00	1,370.39	25.43
182	J794	751.57	1,554.27	J1232	11.77	41.34	20.00	1,370.62	28.25
183	J1592	752.42	2,859.34	J1428	-3.91	30.06	20.00	1,375.21	78.84
184	J1452	752.65	2,453.90	J1428	0.77	30.06	20.00	1,375.44	74.75
185	J746	750.85	2,979.80	J1428	-5.42	30.08	20.00	1,380.20	74.72
186	J1854	751.09	1,637.15	J1460	7.41	43.47	20.00	1,381.15	32.43
187	J1970	751.69	2,350.39	J482	16.35	21.57	20.00	1,382.02	71.58
188	J1108	751.69	1,923.80	J1428	10.87	27.96	20.00	1,383.07	38.33
189	J1496	500.00	2,054.73	J1428	7.16	31.26	20.00	1,384.87	69.55
190	J62	501.57	1,452.58	J1002	15.53	65.49	20.00	1,390.92	24.90
191	J430	753.59	3,337.97	J1052	-41.18	41.75	20.00	1,408.09	82.39
192	J1568	750.49	2,145.41	J482	17.35	21.61	20.00	1,411.21	69.82
193	J1398	751.81	3,240.46	J482	12.03	21.61	20.00	1,412.53	93.13
194	J1318	750.00	2,938.67	J1428	-9.50	27.83	20.00	1,413.34	59.82
195	J50	751.34	2,227.90	J199	-24.20	46.16	20.00	1,448.21	64.23
196	J836	751.12	1,451.46	J836	20.00	46.34	20.00	1,451.46	20.02

## Attachment 2: Updated Fire Flow Model Results

REPLACEMENT Table E-2: South Shore Fire Flow Model Results

	ID	Total Demand (gpm)	Hydrant Available Flow (gpm)	Critical Node ID for Design Run	Critical Node Pressure at Available Flow (psi)	Critical Node Pressure at Fire Demand (psi)	Critical Pressure for Design Run (psi)	Hydrant Design Flow (gpm)	Hydrant Pressure at Design Flow (psi)
197	J1308	505.19	1,730.80	J1310	7.83	51.27	20.00	1,451.65	31.79
198	J1828	501.69	2,853.05	J1482	-38.46	39.93	20.00	1,456.32	56.10
199	J1922	752.69	2,521.68	J1052	-30.28	40.36	20.00	1,457.00	70.29
200	J436	753.36	1,457.56	J436	20.00	77.07	20.00	1,457.55	20.31
201	J1952	751.81	3,047.97	J768	10.86	22.88	20.00	1,465.67	51.99
202	J52	751.57	1,469.84	J52	20.00	45.27	20.00	1,469.84	20.03
203	J490	500.00	1,570.67	J840	16.51	44.97	20.00	1,472.35	28.76
204	J280	751.69	1,922.85	J768	17.56	22.90	20.00	1,474.73	39.12
205	J1926	750.90	1,785.10	J1928	5.86	44.88	20.00	1,481.28	37.64
206	J1368	752.65	1,752.05	J768	18.63	22.91	20.00	1,487.23	36.78
207	J986	501.57	2,077.79	J1428	10.05	31.54	20.00	1,490.22	62.96
208	J584	753.02	1,593.49	J768	19.51	22.92	20.00	1,494.96	25.04
209	J1712	750.67	1,595.77	J272	14.80	49.38	20.00	1,495.80	25.20
210	J1644	750.85	1,496.78	J1644	20.00	53.66	20.00	1,496.78	20.00
211	J928	500.00	1,498.89	J928	20.00	71.85	20.00	1,498.89	20.00
212	J1096	751.12	2,386.64	J199	-29.35	46.83	20.00	1,499.15	71.89
213	J796	751.57	2,917.80	J768	10.92	22.93	20.00	1,501.41	43.33
214	J56	751.21	3,535.55	J768	5.59	22.93	20.00	1,501.56	38.41
215	J894	751.93	1,627.54	J768	19.38	22.93	20.00	1,501.77	25.06
216	J1136	753.14	1,598.01	J768	19.53	22.93	20.00	1,502.98	24.13
217	J704	753.14	2,889.08	J768	11.16	22.93	20.00	1,503.25	36.74
218	J54	751.33	2,105.60	J768	16.72	22.94	20.00	1,506.88	23.31
219	J822	500.49	1,855.66	J1482	-1.57	40.15	20.00	1,513.63	49.59
220	J416	500.00	2,014.20	J1364	-8.50	57.37	20.00	1,517.55	46.38
221	J80	500.70	1,846.97	J1364	1.86	57.37	20.00	1,518.25	47.57
222	J1678	501.57	1,744.60	J1364	7.87	57.37	20.00	1,519.13	38.12
223	J1818	502.29	1,949.89	J1364	-4.30	57.37	20.00	1,519.85	44.45
224	J286	751.93	3,344.81	J1428	-5.82	30.51	20.00	1,524.44	68.33
225	J234	752.69	3,516.88	J1052	-38.94	43.65	20.00	1,563.50	78.50
226	J694	751.34	2,591.59	J199	-35.43	47.62	20.00	1,567.01	80.43
227	J914	751.57	1,574.67	J914	20.00	88.24	20.00	1,574.67	20.01
228	J652	751.12	1,575.69	J652	20.00	41.27	20.00	1,575.69	20.00
229	J1758	500.00	1,576.70	J1758	20.00	85.69	20.00	1,576.70	20.00
230	J1860	502.18	2,106.91	J1484	-3.56	51.87	20.00	1,583.66	43.62
231	J1138	751.34	2,398.58	J199	-15.62	47.62	20.00	1,602.20	64.40
232	J1282	752.24	1,833.24	J199	11.59	47.85	20.00	1,610.60	38.52
233	J1182	750.45	1,841.50	J199	11.39	48.04	20.00	1,617.90	41.49
234	J1862	751.12	2,346.89	J199	-12.38	48.02	20.00	1,618.64	63.46
235	J1124	750.45	1,792.72	J199	13.50	48.12	20.00	1,622.53	35.56
236	J774	751.12	1,702.70	J199	17.18	48.19	20.00	1,629.40	25.58
237	J1834	751.57	1,965.32	J1928	6.22	46.53	20.00	1,636.69	35.61
238	J138	751.79	2,393.57	J199	-14.13	48.33	20.00	1,641.91	66.93
239	J140	751.79	2,205.97	J199	-4.28	48.33	20.00	1,641.91	59.81
240	J446	752.24	2,125.08	J52	-1.28	47.16	20.00	1,642.65	42.16
241	J1422	752.46	2,049.20	J1232	5.27	44.43	20.00	1,662.27	34.78
242	J690	500.00	1,664.16	J690	20.00	62.21	20.00	1,664.16	20.14
243	J874	501.93	1,681.17	J874	20.00	71.33	20.00	1,681.17	20.00
244	J586	750.90	2,137.79	J199	0.61	48.78	20.00	1,683.26	42.25
245	J1804	752.24	3,377.78	J1052	-25.84	45.41	20.00	1,693.31	64.24

## Attachment 2: Updated Fire Flow Model Results

REPLACEMENT Table E-2: South Shore Fire Flow Model Results

	ID	Total Demand (gpm)	Hydrant Available Flow (gpm)	Critical Node ID for Design Run	Critical Node Pressure at Available Flow (psi)	Critical Node Pressure at Fire Demand (psi)	Critical Pressure for Design Run (psi)	Hydrant Design Flow (gpm)	Hydrant Pressure at Design Flow (psi)
246	J738	752.46	1,710.96	J738	20.00	52.12	20.00	1,710.96	20.00
247	J1512	750.00	3,427.12	J1428	-2.84	31.11	20.00	1,711.06	73.94
248	J1486	750.00	2,131.63	J482	18.84	21.84	20.00	1,714.86	42.27
249	J34	750.00	2,652.43	J482	17.12	21.84	20.00	1,714.86	63.24
250	J846	752.46	1,824.49	J52	15.85	47.82	20.00	1,717.15	27.46
251	J1400	759.30	2,890.90	J482	16.27	21.84	20.00	1,724.16	68.05
252	J1120	500.00	1,725.17	J1120	20.00	75.19	20.00	1,725.17	20.05
253	J1270	500.96	1,860.82	J840	15.97	45.89	20.00	1,725.91	29.91
254	J1920	502.90	2,299.51	J840	1.39	45.89	20.00	1,727.84	36.90
255	J102	503.50	2,407.72	J840	-2.56	45.89	20.00	1,728.44	41.45
256	J1864	753.36	1,880.46	J436	5.27	84.11	20.00	1,730.77	35.48
257	J922	751.57	2,102.07	J199	4.42	49.25	20.00	1,732.94	31.52
258	J470	752.46	1,969.60	J52	10.84	47.99	20.00	1,736.55	36.12
259	J1178	752.91	2,307.60	J498	3.51	37.97	20.00	1,753.98	63.18
260	J462	753.59	3,147.98	J1052	-19.23	44.45	20.00	1,758.45	82.57
261	J920	750.00	2,679.51	J199	-22.34	49.55	20.00	1,764.36	65.59
262	J146	752.91	2,711.39	J199	-22.74	49.66	20.00	1,780.98	65.78
263	J1524	750.00	3,442.47	J1428	-1.52	31.31	20.00	1,784.41	74.21
264	J904	751.34	1,788.96	J904	20.00	73.75	20.00	1,788.95	20.00
265	J1240	753.59	1,789.71	J1240	20.00	73.39	20.00	1,789.71	20.01
266	J916	750.00	2,649.20	J199	-17.73	49.84	20.00	1,801.70	60.53
267	J1960	750.00	1,814.57	J1960	20.00	82.53	20.00	1,814.57	20.28
268	J1660	753.80	2,360.83	J498	4.23	38.67	20.00	1,815.48	62.67
269	J148	752.91	2,709.27	J1928	-17.05	47.93	20.00	1,817.29	61.53
270	J106	501.57	1,838.63	J768	19.91	24.18	20.00	1,819.47	20.89
271	J460	500.00	2,865.17	J1482	-22.22	41.13	20.00	1,830.45	51.60
272	J1606	501.57	2,888.98	J768	14.12	24.18	20.00	1,839.71	58.93
273	J1430	753.13	2,747.06	J1052	-5.49	45.03	20.00	1,841.80	67.14
274	J662	504.59	3,513.06	J768	9.90	24.17	20.00	1,845.82	70.33
275	J1602	502.78	2,508.37	J1670	-11.92	51.08	20.00	1,847.77	51.93
276	J1756	503.50	2,486.65	J768	16.75	24.19	20.00	1,855.73	49.04
277	J1342	502.42	2,066.54	J908	8.79	63.49	20.00	1,867.61	30.56
278	J312	750.00	3,661.20	J1052	-24.62	46.28	20.00	1,869.11	54.33
279	J372	750.00	2,544.30	J482	18.24	21.92	20.00	1,869.78	46.35
280	J1278	750.90	1,873.10	J1278	20.00	67.31	20.00	1,873.10	20.00
281	J108	501.81	2,149.66	J1482	9.34	41.19	20.00	1,887.29	30.76
282	J1728	500.00	2,384.48	J768	17.61	24.22	20.00	1,890.44	35.93
283	J762	501.33	2,341.79	J1670	0.29	51.08	20.00	1,899.47	40.55
284	J1166	500.73	3,117.32	J1670	-45.23	52.61	20.00	1,942.52	88.93
285	J528	501.09	2,115.76	J768	19.25	24.25	20.00	1,947.45	27.35
286	J964	752.02	1,981.11	J964	20.00	99.57	20.00	1,981.11	20.00
287	J1230	504.34	3,390.83	J768	13.03	24.26	20.00	1,984.47	51.67
288	J1840	500.00	2,962.68	J1670	-30.57	53.56	20.00	1,986.18	81.01
289	J1938	753.74	3,414.50	J482	16.00	21.98	20.00	1,987.57	67.74
290	J154	504.59	2,603.66	J768	17.33	24.22	20.00	1,988.08	45.82
291	J1902	500.00	2,278.42	J1310	9.39	52.99	20.00	1,990.86	38.69
292	J156	502.90	3,171.25	J768	14.56	24.22	20.00	2,003.38	68.72
293	J1958	750.00	2,409.35	J498	9.61	41.57	20.00	2,006.07	50.63
294	J1468	500.00	2,931.91	J1670	-26.59	54.02	20.00	2,009.23	70.82

## Attachment 2: Updated Fire Flow Model Results

REPLACEMENT Table E-2: South Shore Fire Flow Model Results

		ID	Total Demand (gpm)	Hydrant Available Flow (gpm)	Critical Node ID for Design Run	Critical Node Pressure at Available Flow (psi)	Critical Node Pressure at Fire Demand (psi)	Critical Pressure for Design Run (psi)	Hydrant Design Flow (gpm)	Hydrant Pressure at Design Flow (psi)
295	<input type="checkbox"/>	J724	751.79	2,772.59	J1232	-2.95	46.91	20.00	2,055.75	43.68
296	<input type="checkbox"/>	J648	751.12	2,079.54	J648	20.00	78.03	20.00	2,079.54	20.00
297	<input type="checkbox"/>	J1336	750.26	2,601.39	J1232	4.11	46.98	20.00	2,079.80	52.82
298	<input type="checkbox"/>	J382	751.57	3,384.66	J1232	-25.00	46.98	20.00	2,081.11	72.45
299	<input type="checkbox"/>	J902	751.85	2,117.19	J1232	19.00	46.98	20.00	2,081.39	22.10
300	<input type="checkbox"/>	J346	751.57	3,153.73	J1232	-15.26	47.05	20.00	2,090.62	64.62
301	<input type="checkbox"/>	J804	502.29	3,757.92	J768	11.49	24.29	20.00	2,125.41	62.24
302	<input type="checkbox"/>	J1194	751.12	3,380.84	J1232	-19.27	47.34	20.00	2,168.29	67.90
303	<input type="checkbox"/>	J1806	500.00	2,664.46	J1310	-2.48	53.26	20.00	2,172.25	52.89
304	<input type="checkbox"/>	J952	503.14	2,372.17	J1670	12.78	56.86	20.00	2,183.12	29.36
305	<input type="checkbox"/>	J676	503.98	3,377.58	J1428	5.64	33.09	20.00	2,185.30	72.64
306	<input type="checkbox"/>	J1402	751.34	2,552.13	J652	9.17	44.61	20.00	2,207.96	30.87
307	<input type="checkbox"/>	J1630	501.57	2,285.45	J1364	18.45	60.13	20.00	2,239.87	21.56
308	<input type="checkbox"/>	J1904	500.73	2,930.87	J1310	-10.46	53.28	20.00	2,270.42	59.77
309	<input type="checkbox"/>	J1634	752.24	3,732.81	J1052	-20.80	45.29	20.00	2,308.10	70.34
310	<input type="checkbox"/>	J510	751.57	2,762.36	J652	4.80	45.00	20.00	2,342.42	36.22
311	<input type="checkbox"/>	J988	750.90	2,503.74	J652	15.27	45.10	20.00	2,368.50	25.14
312	<input type="checkbox"/>	J1876	502.42	2,800.77	J1310	3.16	54.24	20.00	2,377.01	44.10
313	<input type="checkbox"/>	J1918	750.00	2,402.41	J1918	20.00	74.31	20.00	2,402.41	20.00
314	<input type="checkbox"/>	J512	751.57	2,596.96	J652	13.52	45.18	20.00	2,409.85	28.45
315	<input type="checkbox"/>	J710	752.91	3,069.12	J1052	3.42	47.81	20.00	2,431.13	38.58
316	<input type="checkbox"/>	J910	752.02	2,432.38	J910	20.00	98.79	20.00	2,432.38	20.00
317	<input type="checkbox"/>	J1654	755.82	2,950.43	J652	0.65	45.29	20.00	2,445.93	41.87
318	<input type="checkbox"/>	J744	750.00	2,512.69	J648	19.13	80.95	20.00	2,495.65	20.90
319	<input type="checkbox"/>	J1082	750.90	2,501.72	J1082	20.00	92.26	20.00	2,499.82	20.00
320	<input type="checkbox"/>	J1530	750.45	2,824.97	J652	7.99	45.46	20.00	2,500.29	36.22
321	<input type="checkbox"/>	J211	1,750.00	3,448.36	J1428	10.13	25.94	20.00	2,502.31	78.21
322	<input type="checkbox"/>	J1696	750.00	2,691.10	J652	14.45	45.71	20.00	2,533.03	26.31
323	<input type="checkbox"/>	J1944	751.12	3,040.83	J652	1.07	45.58	20.00	2,539.82	43.56
324	<input type="checkbox"/>	J640	752.91	3,639.52	J1052	-5.95	45.95	20.00	2,564.54	47.71
325	<input type="checkbox"/>	J926	751.34	2,576.79	J926	20.00	93.21	20.00	2,576.79	20.01
326	<input type="checkbox"/>	J96	751.12	3,042.91	J652	3.82	45.76	20.00	2,601.48	43.86
327	<input type="checkbox"/>	J16	751.57	3,187.97	J1232	8.35	48.84	20.00	2,680.99	39.20
328	<input type="checkbox"/>	J68	751.57	2,700.54	J68	20.00	103.04	20.00	2,700.55	20.19
329	<input type="checkbox"/>	J974	752.91	3,094.71	J1232	12.11	48.95	20.00	2,736.18	33.33
330	<input type="checkbox"/>	J844	752.24	2,762.25	J844	20.00	83.93	20.00	2,762.25	20.01
331	<input type="checkbox"/>	J548	753.59	4,062.11	J1052	-8.61	46.36	20.00	2,786.77	59.91
332	<input type="checkbox"/>	J1843	751.34	2,799.72	J1843	20.00	41.42	20.00	2,799.72	20.04
333	<input type="checkbox"/>	J812	751.57	3,475.08	J652	-2.69	46.32	20.00	2,825.94	48.76
334	<input type="checkbox"/>	J818	752.02	3,940.00	J1052	-0.97	48.13	20.00	2,865.70	51.48
335	<input type="checkbox"/>	J180	751.57	3,267.55	J652	6.65	46.48	20.00	2,869.34	37.19
336	<input type="checkbox"/>	J70	751.79	3,291.19	J652	9.38	46.73	20.00	2,961.51	32.65
337	<input type="checkbox"/>	J1214	751.79	3,819.51	J1052	4.34	47.98	20.00	3,004.13	40.58
338	<input type="checkbox"/>	J72	753.80	3,098.83	J652	17.18	46.82	20.00	3,006.82	23.46
339	<input type="checkbox"/>	J566	755.82	3,046.66	J566	20.00	30.19	20.00	3,046.64	20.06
340	<input type="checkbox"/>	J1849	750.00	3,098.93	J1849	20.00	70.01	20.00	3,098.93	20.09
341	<input type="checkbox"/>	J686	751.34	3,130.57	J686	20.00	52.83	20.00	3,130.57	20.00
342	<input type="checkbox"/>	J1522	754.48	3,705.62	J566	16.60	30.27	20.00	3,193.64	29.14
343	<input type="checkbox"/>	J244	752.24	3,442.06	J566	18.93	30.30	20.00	3,269.77	25.68

Attachment 2: Updated Fire Flow Model Results

REPLACEMENT Table E-2: South Shore Fire Flow Model Results

		ID	Total Demand (gpm)	Hydrant Available Flow (gpm)	Critical Node ID for Design Run	Critical Node Pressure at Available Flow (psi)	Critical Node Pressure at Fire Demand (psi)	Critical Pressure for Design Run (psi)	Hydrant Design Flow (gpm)	Hydrant Pressure at Design Flow (psi)
344	<input type="checkbox"/>	J956	750.90	3,695.33	J566	17.37	30.31	20.00	3,282.54	32.12
345	<input type="checkbox"/>	J1146	752.46	4,113.37	J1052	7.88	48.02	20.00	3,407.68	39.02
346	<input type="checkbox"/>	J680	750.00	4,241.67	J566	14.66	30.58	20.00	3,431.98	47.03
347	<input type="checkbox"/>	J1196	755.37	4,012.16	J566	16.41	30.58	20.00	3,433.76	35.83
348	<input type="checkbox"/>	J440	752.69	3,630.05	J566	18.90	30.59	20.00	3,453.53	28.65
349	<input type="checkbox"/>	J1896	750.00	2,725.65	J272	61.06	61.06			